

TOPIC: Unvented Heater Installation - IMC/9/#1 &

CABO/21/#1

CODE: One & Two Family Dwelling Specialty Code: 1996

Edition

Oregon Mechanical Specialty Code: 1998 Edition

APPROVED: February 1, 2000 [Margaret M. Mahoney]

REFERENCE: Section 2101.1 - One & Two Family Dwelling

Specialty Code

Chapter 9 – Oregon Mechanical Specialty Code

SUBJECT: Installation of Unvented Heaters in Buildings

QUESTION: There are several unvented room heaters available on the market

for installation in residential occupancies. Are these vent free appliances allowed for installation in the City of Portland?

RESPONSE: Unvented room heaters are allowed for installation in any

occupancy classification with the exception of Groups A. E. and I.

In addition, the following conditions must be met:

1. An additional source of heating shall be supplied in dwelling units. An unvented heater cannot be the sole source of heat in any dwelling unit.

- The input rating on an unvented heater shall be less than 40,000 Btu/h (11.7 kW)
- 3. Unvented heaters shall not be installed in sleeping rooms, bathrooms and toilet rooms, storage closets and surgical rooms.
- The aggregate input rating of all unvented appliances installed in a room or space shall not exceed 20 Btu/h per cubic foot (0.21 kW/m³) of volume of the room or space in which the unvented heater is located.
- 5. The unvented heating equipment shall be equipped with an oxygen-depletionsensitive safety shut off system. The system shall be capable of shutting off

IMC/9/#1 & CABO/21/#1 Installation of Unvented Heaters in Buildings Page 2 of 2 February 1, 2000

the gas supply to the main and pilot burners when the oxygen in the surrounding atmosphere is depleted to a percent concentration not lower than 18 percent or in accordance with the manufactures requirements whichever is higher. The shut-off system shall not be allowed to be adjusted.

6. The equipment to be installed shall be listed for the intended use.

New February 1, 2000