



Nick Fish, Commissioner  
Michael Stuhr, P.E., Administrator



1120 SW 5<sup>th</sup> Avenue, Room 600  
Portland, Oregon 97204-1926  
Information: 503-823-7404  
[www.portlandoregon.gov/water](http://www.portlandoregon.gov/water)

July 10, 2017

Chris Silkie, PE, LEED AP, CEM  
Asset Management Program Manager  
Portland Parks & Recreation  
6437 SE Division St, Suite 416  
Portland, OR 97206

RE: Sample Result for Westmoreland Park - Sckavone Stadium

Dear Chris,

Attached you will find the lead result for the water sample collected at Westmoreland Park – Sckavone Stadium on June 29, 2017. The sample was collected in accordance with the protocol outlined in the EPA Technical Guidance, *3Ts for Reducing Lead in Drinking Water in Schools*. The sample was subsequently analyzed at the Portland Water Bureau Laboratory via EPA Method 200.8, an approved method for the analysis of lead in drinking water.

The EPA recommends follow-up testing if lead concentrations in any sample exceeds 20 parts per billion (ppb) to pinpoint the source(s) of lead contamination in your facility. Steps should be taken to mitigate elevated lead levels. Potential mitigation strategies, as well as sampling protocols, are outlined in the EPA guidance - *3Ts for Reducing Lead in Drinking Water in Schools*.

We encourage you to share this result with the public as soon as possible.

Please let us know if you have any questions on these results or any of the other information provided here.

Sincerely,

Yone Akagi, P.E.  
Water Quality Manager  
Portland Water Bureau



**Portland Water Bureau  
Laboratory Report**

**Westmoreland Park - Sckavone Stadium**

<b>PWB Sample ID</b>	<b>Location Description</b>	<b>Date Collected</b>	<b>Time Collected</b>	<b>Lead (ppb)</b>
BB91129	SCKAVONE STADIUM CONCESSIONS SINK	6/29/2017	7:32:00 AM	34.9
BB91130	SCKAVONE STADIUM DUGOUT - SOUTH	6/29/2017	7:36:00 AM	4.87
BB91131	SCKAVONE STADIUM DUGOUT - NORTH	6/29/2017	7:42:00 AM	3.62

ppb = parts per billion



Nick Fish, Commissioner  
Michael Stuhr, P.E., Administrator

1120 SW 5<sup>th</sup> Avenue, Room 600  
Portland, Oregon 97204-1926  
Information: 503-823-7404  
[www.portlandoregon.gov/water](http://www.portlandoregon.gov/water)



August 17, 2017

Chris Silkie, PE, LEED AP, CEM  
Asset Management Program Manager  
Portland Parks & Recreation  
6437 SE Division St, Suite 416  
Portland, OR 97206

RE: Follow-up Sample Results for Westmoreland Park – Sckavone Stadium

Dear Chris,

Attached you will find the lead results for the follow-up water samples collected at Westmoreland Park – Sckavone Stadium on August 11, 2017. Samples were collected based on protocols outlined in the EPA Technical Guidance, *3Ts for Reducing Lead in Drinking Water in Schools*. The samples were subsequently analyzed at the Portland Water Bureau Laboratory via EPA Method 200.8, an approved method for the analysis of lead in drinking water.

The lead results from these follow-up samples are intended to provide additional information on the possible source(s) which are contributing lead to water in your facility. Information on the interpretation of these results, as well as possible mitigation strategies, are outlined in the EPA guidance – *3Ts for Reducing Lead in Drinking Water in Schools*.

We encourage you to share these results with the public as soon as possible.

Please let us know if you have any questions on these results or any of the other information provided here.

Sincerely,

Yone Akagi, P.E.  
Water Quality Manager  
Portland Water Bureau



**Portland Water Bureau  
Laboratory Report**

**Westmoreland Park - Sckavone Stadium**

<b>PWB Sample ID</b>	<b>Location Description</b>	<b>Date Collected</b>	<b>Time Collected</b>	<b>Lead Result (ppb)</b>	<b>Sample Type</b>
BB92828	SCKAVONE STADIUM CONCESSIONS SINK FAUCET	8/11/2017	7:27:00 AM	29.4	First Draw Sample #1 - 125mL
BB92829	SCKAVONE STADIUM CONCESSIONS SINK PIPE	8/11/2017	7:28:00 AM	18.1	First Draw Sample #2 - 125mL
BB92830	SCKAVONE STADIUM CONCESSIONS SINK RUNNING	8/11/2017	7:29:00 AM	1.02	30 Second Flowing Sample

ppb = parts per billion