



Nick Fish, Commissioner
Michael Stuhr, P.E., Administrator



1120 SW 5th Avenue, Room 600
Portland, Oregon 97204-1926
Information: 503-823-7404
www.portlandoregon.gov/water

January 4, 2018

Tom Klutz
Property Acquisition & Services Manager
Portland Water Bureau
1120 SW 5th Ave
Portland, OR 97204

RE: Sample Results for Powell Butte

Dear Tom,

Attached you will find the lead results for the water samples collected from Powell Butte on December 19, 2017. The samples were subsequently analyzed at the Portland Water Bureau Laboratory via EPA Method 200.8, an approved method for the analysis of lead in drinking water.

The EPA recommends follow-up testing if lead concentrations in any sample exceeds 20 parts per billion (ppb) to pinpoint the source(s) of lead contamination in your facility. Steps should be taken to mitigate elevated lead levels. Potential mitigation strategies, as well as sampling protocols, are outlined in the EPA guidance - *3Ts for Reducing Lead in Drinking Water in Schools*.

We encourage you to share these results with the public as soon as possible.

Please let us know if you have any questions on these results or any of the other information provided here.

Sincerely,

Yone Akagi, P.E.
Water Quality Manager
Portland Water Bureau



Portland Water Bureau
Laboratory Report
OR 100014

Powell Butte

PWB Sample ID	Location Description	Date Collected	Time Collected	Lead (ppb)
BB99070	VISITORS CENTER STORAGE ROOM SINK	12/19/2017	7:59:00 AM	7.13
BB99071	MAINTENANCE BUILDING BREAKROOM SINK	12/19/2017	8:05:00 AM	30.2

ppb = parts per billion