



CITY OF PORTLAND ENVIRONMENTAL SERVICES



1120 SW Fifth Avenue, Room 1000, Portland, Oregon 97204 ■ Nick Fish, Commissioner ■ Michael Jordan, Director

February 2019

Stormwater Management Manual Approved Manufactured Stormwater Treatment Technology

Oldcastle PerkFilter™ Media Filtration Device (using ZPC Filter Media)

City of Portland Decision:

The Oldcastle PerkFilter™ Media Filtration Device using ZPC Filter Media meets Portland's pollution reduction requirements, per the requirements of the 2014 Stormwater Management Manual, and is approved for use in the City of Portland with the following conditions.

Background:

As part of the application process, Oldcastle Stormwater Solutions (Oldcastle) submitted the Washington State Department of Ecology (DOE) Technology Assessment Protocol (TAPE) Technology Evaluation Report, including all appendices and performance monitoring data, to demonstrate that the PerkFilter Media Filtration Device (using ZPC Filter Media) meets the City of Portland's pollution reduction requirements.

Oldcastle gave a technical presentation to City staff, Portland State University students and faculty, and the public on July 20, 2016. The presentation was followed by a technical interview with the City of Portland review committee to discuss water quality performance, maintenance and overall use in the public right-of-way.

The City of Portland contracted with Portland State University's Department of Civil and Environmental Engineering (PSU) to provide third-party review of the submitted water quality performance data. PSU analyzed the provided data and found that the PerkFilter Media Filtration Device (using ZPC Filter Media) meets the pollution reduction requirements of the [2014 SWMM](#).

Additional information is available online for this system, including:

- [Oldcastle PerkFilter product website](#)
- [DOE General Use Level Designation](#) (GULD) for Basic (TSS) and Phosphorous Treatment for the PerkFilter Media Filtration Device (using ZPC Filter Media).

Conditions of Use:

1. All configuration options for the PerkFilter Media Filtration Device (using ZPC Filter Media) are approved for pollution reduction. Selection of a specific configuration is the responsibility of the project designer.

Ph: 503-823-7740 Fax: 503-823-6995 ■ www.portlandoregon.gov/bes ■ Using recycled paper ■ An Equal Opportunity Employer

The City of Portland complies with all non-discrimination laws including Title VI (Civil Rights) and Title II (ADA).

To request a translation, accommodation or additional information, please call 503-823-7740, or use City TTY 503-823-6868, or Oregon Relay Service: 711.

2. Use of a PerkFilter Media Filtration Device (using ZPC Filter Media) does not exempt a project or site from required flow control requirements, operations and maintenance requirements, or other applicable requirements of the SWMM.
3. For use in the public right-of-way, the following conditions must be met:
 - Units must meet City of Portland street design requirements, including but not limited to H-20 vehicle load rating, non-slip surface, and American with Disabilities Act tolerances specific to surface grates or vault lids.
 - The O&M Plan must call for an assessment during the two-year warranty period of project-specific maintenance requirements and frequencies.
4. Oldcastle-certified providers should be utilized for activation, inspection and maintenance of the system, unless otherwise trained and certified by the manufacturer.

Project Designer Responsibilities:

1. Ensuring that the conditions of use are met.
2. Ensuring that the project meets all applicable requirements of the Stormwater Management Manual, such as the Stormwater Infiltration and Discharge Hierarchy, in order to use PerkFilter Media Filtration Device (using ZPC Filter Media).
3. Ensuring that the design and installation of the units are appropriate for the project goals, site conditions, long-term maintenance requirements, and any other site-specific design requirements on private property or for use in the public right-of-way.
4. Sizing units to meet the current Stormwater Management Manual presumptive design approach and pollution reduction requirements. The pollution reduction capacity is flow-based and assumes a treatment flow intensity of 0.19 inches per hour, 5 minute time of concentration, and a 0.90 runoff coefficient using the Rational Method with treatment rates based upon WA GULD approved flow rates, in lieu of the manufacturer’s standard flow rate. The treatment capacities for PerkFilter Media Filtration Device (using ZPC Filter Media) units, based on those assumptions, are provided in Table 1. For sites with different times of concentration, different rainfall intensities may be appropriate. See SWMM Chapter 1.3.4, page 1-40 for additional information.

Table 1. PerkFilter (using ZPC Filter Media) Sizing to Meet City of Portland Pollution Reduction Requirements		
Cartridge Size/Stack Configuration	Cartridge Design Flow Rate (gpm/cartridge stack)	Maximum Drainage Area (acres/cartridge stack)
12"	6.8	0.089
18"	10.2	0.133
12" + 12"	13.6	0.177
12" + 18"	17	0.221

5. Each site plan must undergo Oldcastle review before the City of Portland can approve the unit(s) for site installation. A letter that certifies that the project has been designed to manufacturer’s specification must be submitted to BES prior to the appropriate design milestone. For public improvements, including public works permits, the letter must be submitted to BES prior to 60% plan review. For installation on private property, the letter must be submitted prior to building permit plan approval. The project designer is highly encouraged to work with Oldcastle prior to the appropriate review milestone to maximize placement and performance of the unit(s).
6. If the project designer wishes to vary from these conditions of approval, the project designer must use the Performance Design Approach.

General Conditions:

1. BES may at any time suspend or revoke approval if the performance of the technology does not meet performance criteria, or if the performance criteria change due to the local, state, or federal pollution reduction standards.
2. If any changes, updates, or revisions have occurred to the PerkFilter (using ZPC Filter Media), the applicant must obtain DOE TAPE GULD certification and re-apply following submission guidelines in effect at the time of application.

Document Updates:

Date	Action
November 2016	The device was approved for use in the City of Portland.
July 2018	Removed the 3-yr expiration date on BES’ approval, per a change in BES policy.
February 2019	Removed “Cartridges per Impervious Acre” from Table 1 due to the potential for associated sizing errors.