

ARJIGA RUQSADDA AALADAHA PROPANE EE LA QAADAN KARO



Portland Fire & Rescue
Fire Marshal's Office
1300 SE Gideon St.
Portland, OR 97202-2419
Phone: 503-823-3712
Fax: 503-823-3925



Ruqsad waa in loo qaato goob/qol kasta. Kharashka ruqsadu waa \$35 sanadkii.

Sida loo dalbanayo ruqsada:

- Buuxi oo soo gudbi arjiga lacagtana soo raaci. Hadii aanad lacag la bixin ruqsada lama bixinayo.
- Usoo dir ama u keen arjiga aad buuxisay iyo \$35 oo lacag ah:
1300 SE Gideon St., Portland, OR 97202. (Jeegaga waxaa lagu bixin karaa "Portland City Treasurer")
Saacadaha Shaqada: 8:00 sunaxnimo -3:30 galabnimo, Isniin – Jimce.
- Arjiga sidoo kale waxaa lau diri karaa iimeelka pfrpc@portlandoregon.gov. Kadibna wac si aad lacagta ugu bixiso kiridhid kaadhka.

**Xogta soo socota buuxi oo akhri dhamaan shuruudaha labada dhinacba ee arjiga ku qoran.
Ruqsada waa lala noqon karaa ama ganaax ayaa la saari karaa hadii shuruudaha aan la raacin .**

Nooca shaqada: miis la riixo/taagan gaadhi cunto qol munaasabado/dabaal degyo
 waxkale (sheeg): _____

Magaca Dalbaha: _____

Magaca Ganacsiga: _____

Mulkiilaha Ganacsiga: _____

Cinwaanka Boosta: _____

Taleefanka Lagala Xidhiidhyo: _____

Halka alaabta la dhigayo: _____

(magaca munaasabada ama cinwaanka goobta miiska/gaadhiga cuntada)

- Waan akhriyay, fahmay waxaana raaci doonaa shuruudaha dhabarka foomkan ku qoran. Sidoo kale, waxaan xogta siin doonaa shaqaalaha goobta ka shaqaynaya. Waxaan fahansanahay hadii loo hogaansami waayo shuruudaha inay keeni karto in ruqsada lala noqdo ama ganaax lagu mutaysan karo.

Saxeexa: _____

Taariikh: _____

Fadlan Ruqsada Meel La Arkayo Soo Dhig

Xafiiska Ayaa Isticmaalaya	
Taariikh: _____	Lambarka Ruqsada: _____
Kaash <input type="checkbox"/>	Jeeg #: _____
Risiidh #: _____	
Laga Heley: _____	
Ruqsada Waxaa Bixiyay: _____	

SHURUUDAHA ISTICMAALKA AALADAH PROPANE EE LA QAADAN KARO EE SHIDAALKA KU SHAQAYSA

Dhamaan dadka miisaska raashinka ku sameeyaa ee propane isticmaalaa waa inay haystaan ruqsada propane ee hada waana inay soo dhigaan meel miiska/golka ah oo la arkayo.

Hadii ayna awoodin inay soo dhigaan, waa in qofka ka shaqaynayaa uu meesha ku hayo ruqsada marka loo baahdo.

1. Goob kasta oo lagu haysto propane-ka wareega waxaa qasab ku ah in lagu hayo meeshaa **2A-10BC ama dab damiye tayo sare**. Waxaa qasab ah **dab damiyaha K-Class** hadii wax lagu karinayo waxyaabaha aad wax u shiila ama qalabka kale isticmaala $\frac{1}{4}$ inji oo saliid ah ama gaas ah. **Dhamaan dab damiyayaashu** waa in sanadkii laga shaqeeyaa waana inay sumadii waqtigaa ee shirkad dab damis oo la garanayo lahaataa.
2. Weelka ay ku jirto propane-tu ha dhigin dhisme dhexdii ama meel soo xidhan. Waa in uu taangigu banaanka ka yaalaa meesha cuntada lagu samaynayo.
3. Marka aan shoolada la isticmaalaynin ama taangiga laga badalaynin, waa in gaasta **laga xidhaa taangiga**(kaliya waa inaan shoolada laga xidhin).
4. Waa in alaabta laga fogeeyaa ololka ama qalabka shoodhka dhaliya si looga ilaaliyo in uu aad u kululaado. Waa in ugu yaraan shoolada iyo agabka uu u dhaxeeyaa hal fuut oo banaan ahi.
5. Waa in dhamaan agabka iyo shoolada shidaalka loo isticmaalayo loo ansixiyaa in propane loo isticmaali karo.
6. Dhamaan alaabta waa in dhaawaca laga ilaaliyaa.
7. Meelaha laga maamula waa in si fudud loo gaadhi karaa.
8. Shooladaha qaar aan ololka la arkaynin marka lagu shaqaynayo waa in ay jirtaa qalab si toos ah looga bakhtiin karo.
9. Miiska/gaadhiga raashinku kaliya waxay qaadan karaan shidaal laba todobaad ah oo kaliya(ugu badnaan taangi ay 25 galaan ku jiraan).
10. Dhamaan waa in qalabka loo isticmaalaa sida loo sameeyay ee loogu talo galay.
 - Taangiga dherarka loo sameeyay in loo isticmaalo waa in aan la jiifin marka la isticmaalayo.
 - Taangiyada ka wayn 5-ta galaan waa in kor loo xidhaa si ayna u dhicin ama isu garaacin .
 - Waa in qalab laga maamulo lagu rakibaa taangi kasta. Hadii la isticmaalayo gaasta kala duwan , ilaa laba taangi ayaa laga wada maamuli karaa qalab kaliya.
 - Dhamaan taangiyada waa in raqabada loo ilaaliyaa waana in uu u bad qabaa.
 - Dhamaan taangiyadu waa inay leeyihiin shaambada taariikhda tijaabada hydrostatic.
 - Taangiyada propane-ta lalama xidhi karo/meel lalama dhigi karo taangiyada kaarboon dhi'ogsaydhka ah (CO₂).
 - Dhamaan taangiyada waa in ay lahaadaan Qalabka Ka Ilaalinaya In La Buux Dhaafiyo (OPD). Taangiyada aan lahayn qalabkan lama ogola.
 - Sharooto haku dhajinin inta xidhiidhisa qalabka halka laga maamulo iyo taangiga propane-ta. Xidhiidhiyahan waxaa loogu talo galay in bir iyo bir istaabtaan.
 - Waa in la badalaa hadii ay waxyeelo soo gaasho qalabka halka laga maamulo, xidhiidhiyaha iyo tuubada .
 - La iskuma xidhi karo ka keena.
 - Tuubada u dhaxeeya qalabka laga maamulo iyo gaasaska kala duwan kama badan karo dherarkiisu laba fuut.
 - Kaliya waxaa la ogol yahay in la isticmaalo propane-ta la ogol yahay. Lama ogola in la isticmaalo noocyade kale ee sida diyaaradaha, gaadiida, iyo noocyada kale.
 - Tuubada keenaysa waa in uu dherar fiican oo uu iskugu xidhi karo shoolada iyo taangiga leeyahay, balse aanu ka dheerayn.
11. Shidaalka propane-ta in shoolada **kulayl** loogu isticmaalo gudaha **lama ogola** waxay doonto xaaladu ha ahaatee. Waxaa kamid ah taas, balse aanay ku koobnayn teendhooyinka iyo dhismayaasha kale ee banaanka loogu talo galay.