



Nick Fish, Commissioner
Michael Stuhr, P.E., Administrator

1120 SW 5th Avenue, Room 600
Portland, Oregon 97204-1926
Information: 503-823-7404
www.portlandoregon.gov/water



June 14, 2016

Dear Mr. O'Longaigh:

Attached you will find the lead results for the water samples collected at your facility on June 9, 2016. Samples were collected in accordance with the protocol outlined in the EPA Technical Guidance, *3Ts for Reducing Lead in Drinking Water in Schools*. The 250 mL water samples were subsequently analyzed at the Portland Water Bureau Laboratory via EPA method 200.8, an approved method for the analysis of lead in drinking water.

EPA recommends follow up testing if lead concentrations in any sample exceeds 20 parts per billion (ppb) to pinpoint the source(s) of lead contamination in your facility. Steps should be taken to mitigate elevated lead levels, and potential mitigation strategies are also outlined in *3Ts for Reducing Lead in Drinking Water in Schools*.

We encourage you to share these results with the public as soon as possible.

Please let us know if you have any questions on these results or any of the other information provided here.

Sincerely,

Yone Akagi, P.E.
Water Quality Compliance Manager



**Portland Water Bureau
Laboratory Report**

Sample ID	Facility	Location Description	Date Collected	Time Collected	Lead (ppb)	Standing Time (hours)
BB64746	City Kids	Kitchen East Sink (2c)	6/9/2016	5:26:00 AM	1.55	11.03
BB64747	City Kids	Kitchen West Sink (2c)	6/9/2016	5:28:00 AM	1.63	11.03
BB64748	City Kids	Work Storage Sink (1g)	6/9/2016	5:31:00 AM	2.54	11.08
BB64749	City Kids	Toddler Classroom Sink (15)	6/9/2016	5:34:00 AM	0.7	11.07
BB64750	City Kids	Main Room Drinking Fountain	6/9/2016	5:37:00 AM	0.13	10.97
BB64751	City Kids	Young Preschool Sink (RM 106)	6/9/2016	5:40:00 AM	2.11	11.13
BB64752	City Kids	Young Preschool Bathroom Left	6/9/2016	5:45:00 AM	3.68	11.18
BB64753	City Kids	Young Preschool Bathroom Right	6/9/2016	5:47:00 AM	1.45	11.22
BB64754	City Kids	Wobblers Classroom NE Sink	6/9/2016	5:52:00 AM	0.8	11.15
BB64755	City Kids	Infant Classroom Sink	6/9/2016	5:56:00 AM	2.3	11.25
BB64756	City Kids	Preschool Room West Sink	6/9/2016	5:59:00 AM	1.41	11.37
BB64757	City Kids	Preschool Room East Sink	6/9/2016	6:00:00 AM	0.53	11.38

ppb = parts per billion