



Nick Fish, Commissioner
Michael Stuhr, P.E., Administrator

1120 SW 5th Avenue, Room 600
Portland, Oregon 97204-1926
Information: 503-823-7404
www.portlandoregon.gov/water



July 18, 2016

Dear Mr. Silkie:

Attached you will find the lead results for the water samples collected at Charles Jordan Community Center on July 1, 2016. Samples were collected in accordance with the protocol outlined in the EPA Technical Guidance, *3Ts for Reducing Lead in Drinking Water in Schools*. The 250 mL water samples were subsequently analyzed at the Portland Water Bureau Laboratory via EPA Method 200.8, an approved method for the analysis of lead in drinking water.

The EPA recommends follow-up testing if lead concentrations in any sample exceeds 20 parts per billion (ppb) to pinpoint the source(s) of lead contamination in your facility. Steps should be taken to mitigate elevated lead levels. Potential mitigation strategies, as well as sampling protocols, are outlined in the EPA guidance - *3Ts for Reducing Lead in Drinking Water in Schools*.

We encourage you to share these results with the public as soon as possible.

Please let us know if you have any questions on these results or any of the other information provided here.

Sincerely,

Yone Akagi, PE
Water Quality Compliance Manager



**Portland Water Bureau
Laboratory Report**

PWB Sample ID	Location Description	Date Collected	Time Collected	Lead (ppb)
BB67705	1-101 -DF-1: Lobby 101	7/1/2016	5:12:00 AM	0.82
BB67706	1-101 -DF-2: Lobby 101	7/1/2016	5:13:00 AM	0.84
BB67707	1-103 -SINK-1: Classroom 103	7/1/2016	5:16:00 AM	0.61
BB67708	1-103 -SINK-2: Classroom 103	7/1/2016	5:17:00 AM	1.38
BB67709	1-108 -DF-1: Corridor 108	7/1/2016	5:19:00 AM	0.17
BB67710	1-108 -DF-2: Corridor 108	7/1/2016	5:19:00 AM	0.17
BB67711	1-112 -SINK-1: Pre-School 112	7/1/2016	5:21:00 AM	1.9
BB67712	1-118 -SINK-1: Pre-School 118	7/1/2016	5:22:00 AM	2.19
BB67713	1-128 -DF-1: Teen Lounge 128	7/1/2016	5:24:00 AM	0.25
BB67714	1-128 -DF-2: Teen Lounge 128	7/1/2016	5:24:00 AM	0.25
BB67715	1-134 -DF-1: Gym 134	7/1/2016	5:27:00 AM	0.45
BB67716	1-134 -DF-2: Gym 134	7/1/2016	5:28:00 AM	0.41
BB67717	1-158 -SINK-1: Multi-Purpose R	7/1/2016	5:31:00 AM	0.86
BB67718	1-159 -DF-1: Corridor 159	7/1/2016	5:32:00 AM	0.46
BB67719	1-159 -DF-2: Corridor 159	7/1/2016	5:33:00 AM	0.38
BB67720	1-160 -SINK-1: Kitchen 160	7/1/2016	5:36:00 AM	1.16
BB67721	1-160 -SINK-2: Kitchen 160	7/1/2016	5:37:00 AM	0.56
BB67722	1-160 -SINK-3: Kitchen 160	7/1/2016	5:38:00 AM	1.04
BB67723	1-160 -SINK-4: Kitchen 160	7/1/2016	5:38:00 AM	1.05
BB67724	1-164 -SINK-1: Classroom 164	7/1/2016	5:39:00 AM	1.26
BB67725	1-166 -SINK-1: Lounge 166	7/1/2016	5:40:00 AM	0.78
BB67726	1-173 -DF-1: Lobby 173	7/1/2016	5:44:00 AM	0.32
BB67727	1-173 -DF-2: Lobby 173	7/1/2016	5:44:00 AM	0.18
BB67728	1-173 -DF-3: Lobby 173	7/1/2016	5:45:00 AM	0.41
BB67729	1-173 -DF-4: Lobby 173	7/1/2016	5:46:00 AM	0.41
BB67730	1-178 -SINK-1: Classroom 178	7/1/2016	5:48:00 AM	0.89
BB67731	1-180 -SINK-1: Classroom 180	7/1/2016	5:49:00 AM	1.04

ppb = parts per billion