



Nick Fish, Commissioner
Michael Stuhr, P.E., Administrator

1120 SW 5th Avenue, Room 600
Portland, Oregon 97204-1926
Information: 503-823-7404
www.portlandoregon.gov/water



August 1, 2016

Chris Silkie, PE, LEED AP, CEM
Asset Management Program Manager
Portland Parks & Recreation
6437 SE Division St, Suite 416
Portland, OR 97206

RE: Sample Results for Matt Dishman Community Center & Indoor Pool

Dear Chris,

Attached you will find the lead results for the water samples collected at Matt Dishman Community Center & Indoor Pool on July 15, 2016. Samples were collected in accordance with the protocol outlined in the EPA Technical Guidance, *3Ts for Reducing Lead in Drinking Water in Schools*. The 250 mL water samples were subsequently analyzed at the Bureau of Environmental Services Water Pollution Control Laboratory via EPA Method 200.8, an approved method for the analysis of lead in drinking water.

The EPA recommends follow-up testing if lead concentrations in any sample exceeds 20 parts per billion (ppb) to pinpoint the source(s) of lead contamination in your facility. Steps should be taken to mitigate elevated lead levels. Potential mitigation strategies, as well as sampling protocols, are outlined in the EPA guidance - *3Ts for Reducing Lead in Drinking Water in Schools*.

We encourage you to share these results with the public as soon as possible.

Please let us know if you have any questions on these results or any of the other information provided here.

Sincerely,

Yone Akagi, PE
Water Quality Compliance Manager



Portland Water Bureau Laboratory Report

Matt Dishman Community Center & Indoor Pool

PWB Sample ID	Location Description	Date Collected	Time Collected	Lead (ppb)
BB69027	1-102-DF-1	7/15/2016	4:00:00 AM	0.305
BB69028	1-105-DF-2	7/15/2016	4:03:00 AM	0.422
BB69029	1-105-DF-1	7/15/2016	4:04:00 AM	0.348
BB69030	1-101-DF-1	7/15/2016	4:06:00 AM	<0.101
BB69031	1-101-DF-2	7/15/2016	4:08:00 AM	0.102
BB69032	1-139-SINK-1	7/15/2016	4:09:00 AM	1.55
BB69033	1-135-DF-1	7/15/2016	4:10:00 AM	0.211
BB69034	1-135-DF-2	7/15/2016	4:11:00 AM	0.129
BB69035	1-131-DF-1	7/15/2016	4:15:00 AM	0.116
BB69036	1-128-SINK-1	7/15/2016	4:16:00 AM	0.848
BB69037	1-129-SINK-1	7/15/2016	4:18:00 AM	4.16
BB69038	1-129-SINK-2	7/15/2016	4:18:00 AM	3.47
BB69039	1-119-DF-1	7/15/2016	4:25:00 AM	0.221
BB69040	1-111-DF-1	7/15/2016	5:00:00 AM	0.493

ppb = parts per billion