



Nick Fish, Commissioner  
Michael Stuhr, P.E., Administrator

1120 SW 5<sup>th</sup> Avenue, Room 600  
Portland, Oregon 97204-1926  
Information: 503-823-7404  
[www.portlandoregon.gov/water](http://www.portlandoregon.gov/water)



August 17, 2016

Chris Silkie, PE, LEED AP, CEM  
Asset Management Program Manager  
Portland Parks & Recreation  
6437 SE Division St, Suite 416  
Portland, OR 97206

RE: Sample Results for Mt. Scott Community Center & Indoor Pool

Dear Chris,

Attached you will find the lead results for the water samples collected at Mt. Scott Community Center & Indoor Pool on July 29, 2016. Samples were collected in accordance with the protocol outlined in the EPA Technical Guidance, *3Ts for Reducing Lead in Drinking Water in Schools*. The samples were subsequently analyzed at the Portland Water Bureau Laboratory via EPA Method 200.8, an approved method for the analysis of lead in drinking water.

The EPA recommends follow-up testing if lead concentrations in any sample exceeds 20 parts per billion (ppb) to pinpoint the source(s) of lead contamination in your facility. Steps should be taken to mitigate elevated lead levels. Potential mitigation strategies, as well as sampling protocols, are outlined in the EPA guidance - *3Ts for Reducing Lead in Drinking Water in Schools*.

We encourage you to share these results with the public as soon as possible.

Please let us know if you have any questions on these results or any of the other information provided here.

Sincerely,

Yone Akagi, PE  
Water Quality Compliance Manager



**Portland Water Bureau  
Laboratory Report**

**Mt. Scott Community Center & Indoor Pool**

<b>PWB Sample ID</b>	<b>Location Description</b>	<b>Date Collected</b>	<b>Time Collected</b>	<b>Lead (ppb)</b>
BB71507	1-100-DF-1 Lobby 100	7/29/2016	5:01:00 AM	0.38
BB71508	1-100-DF-2 Lobby 100	7/29/2016	5:01:00 AM	0.28
BB71509	1-102-SINK-1 Kitchen 102	7/29/2016	5:06:00 AM	3.66
BB71510	1-131-LAV-1 Restroom 131	7/29/2016	5:08:00 AM	1.71
BB71511	1-107-DF-1 Gym 107	7/29/2016	5:11:00 AM	1.16
BB71512	2-201-SINK-1 Arts & Crafts Room 201 wall	7/29/2016	5:14:00 AM	5.33
BB71513	2-201-SINK-2 Arts & Crafts Room 201 corner	7/29/2016	5:14:00 AM	11.1
BB71514	1-106-DF-1 Fitness Center 106 L	7/29/2016	5:17:00 AM	0.11
BB71515	1-106-DF-2 Fitness Center 106 R	7/29/2016	5:17:00 AM	0.18
BB71516	1-152-DF-1 Aquatics Lobby 152 L	7/29/2016	5:19:00 AM	0.36
BB71517	1-152-DF-2 Aquatics Lobby 152 R	7/29/2016	5:19:00 AM	0.55
BB71518	1-154-SINK-1 Lifeguard 154	7/29/2016	5:21:00 AM	0.21
BB71519	1-109-SINK-1 Poolside Room B 109 L	7/29/2016	5:26:00 AM	1.18
BB71520	1-109-SINK-2 Poolside Room B 109 R	7/29/2016	5:26:00 AM	2.14
BB71521	1-110-DF-1 Leisure Pool 110 L	7/29/2016	5:29:00 AM	0.6
BB71522	1-110-DF-2 Leisure Pool 110 R	7/29/2016	5:29:00 AM	0.37
BB71523	B-002-DF-1 Basement Restroom DF	7/29/2016	5:32:00 AM	0.49
BB71524	B-001-SINK-1 Rink side Room 001	7/29/2016	5:31:00 AM	3.75
BB71525	1-OUT-DF-1 DF E of Restroom in Play Area	7/29/2016	5:40:00 AM	0.26

ppb = parts per billion