

Nick Fish, Commissioner Michael Stuhr, P.E., Administrator

1120 SW 5<sup>th</sup> Avenue, Room 600 Portland, Oregon 97204-1926 Information: 503-823-7404 www.portlandoregon.gov/water



August 17, 2016

Chris Silkie, PE, LEED AP, CEM
Asset Management Program Manager
Portland Parks & Recreation
6437 SE Division St, Suite 416
Portland, OR 97206

RE: Sample Results for Interstate Firehouse Cultural Center

Dear Chris,

Attached you will find the lead results for the water samples collected at Interstate Firehouse Cultural Center on August 4, 2016. Samples were collected in accordance with the protocol outlined in the EPA Technical Guidance, 3Ts for Reducing Lead in Drinking Water in Schools. The samples were subsequently analyzed at the Portland Water Bureau Laboratory via EPA Method 200.8, an approved method for the analysis of lead in drinking water.

The EPA recommends follow-up testing if lead concentrations in any sample exceeds 20 parts per billion (ppb) to pinpoint the source(s) of lead contamination in your facility. Steps should be taken to mitigate elevated lead levels. Potential mitigation strategies, as well as sampling protocols, are outlined in the EPA guidance - 3Ts for Reducing Lead in Drinking Water in Schools.

We encourage you to share these results with the public as soon as possible.

Please let us know if you have any questions on these results or any of the other information provided here.

Sincerely,

Yone Akagi, PE

Water Quality Compliance Manager



## **Laboratory Report**

## **Interstate Firehouse Cultural Center**

PWB		Date	Time	Lead
Sample ID	Location Description	Collected	Collected	(ppb)
BB72157	1-100-DF-1 Lobby 100	8/4/2016	5:46:00 AM	17.9
BB72158	2-201-BF-1 Lobby 201 BF	8/4/2016	5:50:00 AM	3.49
BB72159	2-201-DF-1 Lobby 201 L	8/4/2016	5:50:00 AM	4.09
BB72160	2-201-DF-2 Lobby 201 R	8/4/2016	5:51:00 AM	4.5
BB72161	2-205-SINK-1 Kitchen 205	8/4/2016	5:53:00 AM	6.94

ppb = parts per billion