



Nick Fish, Commissioner
Michael Stuhr, P.E., Administrator

1120 SW 5th Avenue, Room 600
Portland, Oregon 97204-1926
Information: 503-823-7404
www.portlandoregon.gov/water



August 17, 2016

Chris Silkie, PE, LEED AP, CEM
Asset Management Program Manager
Portland Parks & Recreation
6437 SE Division St, Suite 416
Portland, OR 97206

RE: Sample Results for Columbia Indoor Pool

Dear Chris,

Attached you will find the lead results for the water samples collected at Columbia Indoor Pool on August 4, 2016. Samples were collected in accordance with the protocol outlined in the EPA Technical Guidance, *3Ts for Reducing Lead in Drinking Water in Schools*. The samples were subsequently analyzed at the Portland Water Bureau Laboratory via EPA Method 200.8, an approved method for the analysis of lead in drinking water.

The EPA recommends follow-up testing if lead concentrations in any sample exceeds 20 parts per billion (ppb) to pinpoint the source(s) of lead contamination in your facility. Steps should be taken to mitigate elevated lead levels. Potential mitigation strategies, as well as sampling protocols, are outlined in the EPA guidance - *3Ts for Reducing Lead in Drinking Water in Schools*.

We encourage you to share these results with the public as soon as possible.

Please let us know if you have any questions on these results or any of the other information provided here.

Sincerely,

Yone Akagi, PE
Water Quality Compliance Manager



Portland Water Bureau Laboratory Report

Columbia Indoor Pool

PWB Sample ID	Location Description	Date Collected	Time Collected	Lead (ppb)
BB72154	1-111-SINK-1 Staff/Party Room	8/4/2016	5:29:00 AM	1.77
BB72155	1-121-DF-1 West side of pool deck L	8/4/2016	5:29:00 AM	2.36
BB72156	1-121-DF-2 West side of pool deck R	8/4/2016	5:30:00 AM	1.34

ppb = parts per billion