



Nick Fish, Commissioner  
Michael Stuhr, P.E., Administrator

1120 SW 5<sup>th</sup> Avenue, Room 600  
Portland, Oregon 97204-1926  
Information: 503-823-7404  
[www.portlandoregon.gov/water](http://www.portlandoregon.gov/water)



September 7, 2016

Chris Silkie, PE, LEED AP, CEM  
Asset Management Program Manager  
Portland Parks & Recreation  
6437 SE Division St, Suite 416  
Portland, OR 97206

RE: Sample Results for East Portland Community Center

Dear Chris,

Attached you will find the lead results for the water samples collected at East Portland Community Center on August 19, 2016. Samples were collected in accordance with the protocol outlined in the EPA Technical Guidance, *3Ts for Reducing Lead in Drinking Water in Schools*. The samples were subsequently analyzed at the Portland Water Bureau Laboratory via EPA Method 200.8, an approved method for the analysis of lead in drinking water.

The EPA recommends follow-up testing if lead concentrations in any sample exceeds 20 parts per billion (ppb) to pinpoint the source(s) of lead contamination in your facility. Steps should be taken to mitigate elevated lead levels. Potential mitigation strategies, as well as sampling protocols, are outlined in the EPA guidance - *3Ts for Reducing Lead in Drinking Water in Schools*.

We encourage you to share these results with the public as soon as possible.

Please let us know if you have any questions on these results or any of the other information provided here.

Sincerely,

Yone Akagi, PE  
Water Quality Compliance Manager



**Portland Water Bureau  
Laboratory Report**

FROM FOREST TO FAUCET OR 100014

**East Portland Community Center**

<b>PWB Sample ID</b>	<b>Location Description</b>	<b>Date Collected</b>	<b>Time Collected</b>	<b>Lead (ppb)</b>
BB73836	1-101-DF-1 Lobby 101 L	8/19/2016	4:57:00 AM	0.055
BB73837	1-101-DF-2 Lobby 101 R	8/19/2016	4:57:00 AM	<0.05
BB73838	1-105-SINK-1 Work Room 105	8/19/2016	5:00:00 AM	1.19
BB73839	1-115-DF-1 Corridor 115 across	8/19/2016	4:58:00 AM	<0.05
BB73840	1-115-DF-2 Corridor 115 across	8/19/2016	4:58:00 AM	<0.05
BB73841	1-109-SINK-1 Classroom 1 109	8/19/2016	5:03:00 AM	2.01
BB73842	1-108A-LAV-1 Changing Room 108	8/19/2016	5:05:00 AM	1.4
BB73843	1-108A-LAV-2 Changing Room 108	8/19/2016	5:05:00 AM	1.67
BB73844	1-108-SINK-1 Child Center 108	8/19/2016	5:06:00 AM	2.08
BB73845	1-108-DF-1 Child Center 108 Fo	8/19/2016	5:06:00 AM	2.28
BB73846	1-116-SINK-2 Kitchen 116 E	8/19/2016	5:11:00 AM	4.28
BB73847	1-116-ICE-1 Kitchen 116 Ice Ma	8/19/2016	5:12:00 AM	<0.05
BB73848	1-116-SINK-4 Kitchen 116 SW	8/19/2016	5:13:00 AM	17.8
BB73849	1-110-SINK-1 Classroom 2 110	8/19/2016	5:09:00 AM	1.15
BB73850	1-122-DF-1 Gym NE entrance	8/19/2016	5:16:00 AM	0.12
BB73851	1-122-BF-1 Gym NE entrance	8/19/2016	5:16:00 AM	0.49
BB73852	1-122-DF-2 Gym SE entrance	8/19/2016	5:18:00 AM	0.23
BB73853	1-122-BF-2 Gym SE entrance	8/19/2016	5:18:00 AM	0.54
BB73854	1-125-DF-1 Weight room 125	8/19/2016	5:19:00 AM	0.21
BB73855	1-163-DF-1 Corridor 163 L	8/19/2016	5:22:00 AM	0.95
BB73856	1-163-DF-2 Corridor 163 R	8/19/2016	5:21:00 AM	1.67
BB73857	1-139-SINK-1 BP Room 139	8/19/2016	5:23:00 AM	14.3
BB73858	1-140-SINK-1 BP Room 140	8/19/2016	5:24:00 AM	23
BB73859	1-135-SINK-1 Lifeguard 135	8/19/2016	5:25:00 AM	0.84
BB73860	1-130-DF-1 Pool deck DF NW cor	8/19/2016	5:27:00 AM	3.13
BB73861	1-130-DF-2 Pool deck DF NW cor	8/19/2016	5:27:00 AM	2.51

ppb = parts per billion