



Nick Fish, Commissioner
Michael Stuhr, P.E., Administrator

1120 SW 5th Avenue, Room 600
Portland, Oregon 97204-1926
Information: 503-823-7404
www.portlandoregon.gov/water



September 26, 2016

Shawn Roberti
Sr. Facilities Maintenance Supervisor
Portland Fire and Rescue
1135 SE Powell Blvd
Portland, OR 97214

RE: Sample Results for The Historic Belmont Firehouse

Dear Shawn,

Attached you will find the lead results for the water samples collected at The Historic Belmont Firehouse on August 24, 2016. Samples were collected in accordance with the protocol outlined in the EPA Technical Guidance, *3Ts for Reducing Lead in Drinking Water in Schools*. The samples were subsequently analyzed at the Portland Water Bureau Laboratory via EPA Method 200.8, an approved method for the analysis of lead in drinking water.

The EPA recommends follow-up testing if lead concentrations in any sample exceeds 20 parts per billion (ppb) to pinpoint the source(s) of lead contamination in your facility. Steps should be taken to mitigate elevated lead levels. Potential mitigation strategies, as well as sampling protocols, are outlined in the EPA guidance - *3Ts for Reducing Lead in Drinking Water in Schools*.

We encourage you to share these results with the public as soon as possible.

Please let us know if you have any questions on these results or any of the other information provided here.

Sincerely,

Yone Akagi, PE
Water Quality Compliance Manager



**Portland Water Bureau
Laboratory Report**

OR 100014

The Historic Belmont Firehouse

PWB Sample ID	Location Description	Date Collected	Time Collected	Lead (ppb)
BB74152	Kitchen Sink	8/24/2016	7:49:00 AM	2.99
BB74153	Drinking Fountain at Utility Sink	8/24/2016	7:50:00 AM	95.4

ppb = parts per billion