



Nick Fish, Commissioner
Michael Stuhr, P.E., Administrator

1120 SW 5th Avenue, Room 600
Portland, Oregon 97204-1926
Information: 503-823-7404
www.portlandoregon.gov/water



October 13, 2016

Barbara Erspamer
Administrative Supervisor
Portland Police Bureau – North Precinct
449 NE Emerson
Portland, OR 97211

RE: Sample Results for North Precinct

Dear Barbara,

Attached you will find the lead results for the water samples collected at North Precinct on September 27, 2016. Samples were collected in accordance with the protocol outlined in the EPA Technical Guidance, *3Ts for Reducing Lead in Drinking Water in Schools*. The samples were subsequently analyzed at the Portland Water Bureau Laboratory via EPA Method 200.8, an approved method for the analysis of lead in drinking water.

The EPA recommends follow-up testing if lead concentrations in any sample exceeds 20 parts per billion (ppb) to pinpoint the source(s) of lead contamination in your facility. Steps should be taken to mitigate elevated lead levels. Potential mitigation strategies, as well as sampling protocols, are outlined in the EPA guidance - *3Ts for Reducing Lead in Drinking Water in Schools*.

We encourage you to share these results with the public as soon as possible.

Please let us know if you have any questions on these results or any of the other information provided here.

Sincerely,

Yone Akagi, PE
Water Quality Compliance Manager



**Portland Water Bureau
Laboratory Report**

Portland Police Bureau - North Precinct

PWB Sample ID	Location Description	Date Collected	Time Collected	Lead (ppb)
BB76801	Fountain Left Outside RM 169	9/27/2016	6:30:00 AM	<0.05
BB76802	Fountain Right Outside RM 169	9/27/2016	6:30:00 AM	<0.05
BB76803	Bottle Filler Right Outside RM 169	9/27/2016	6:30:00 AM	<0.05
BB76804	Kitchen Sink RM 202	9/27/2016	6:33:00 AM	1.82
BB76805	Weight Room 215 Fountain	9/27/2016	6:35:00 AM	<0.05
BB76806	Weight Room 215 Bottle Filler	9/27/2016	6:35:00 AM	<0.05
BB76807	Downstairs Kitchenette Bottle Filler	9/27/2016	6:28:00 AM	0.12
BB76808	Downstairs Kitchenette Sink	9/27/2016	6:28:00 AM	1.53
BB76809	Community Room Kitchenette	9/27/2016	6:37:00 AM	9.79
BB76810	Youth Services Dev. Sink South	9/27/2016	6:41:00 AM	6.12
BB76811	Youth Services Dev. Kitchen North	9/27/2016	6:42:00 AM	1.94
BB76812	Office of Youth Violence Sink	9/27/2016	6:44:00 AM	9.28

ppb = parts per billion