



Nick Fish, Commissioner
Michael Stuhr, P.E., Administrator

1120 SW 5th Avenue, Room 600
Portland, Oregon 97204-1926
Information: 503-823-7404
www.portlandoregon.gov/water



February 6, 2017

Jenny Martinez
City of Portland – Bureau of Environmental Services
6543 N Burlington Ave
Portland, OR 97203

RE: Sample Results for the Water Pollution Control Laboratory

Dear Jenny,

Attached you will find the lead results for the water samples collected at the Water Pollution Control Laboratory on January 20, 2017. Samples were collected in accordance with the protocol outlined in the EPA Technical Guidance, *3Ts for Reducing Lead in Drinking Water in Schools*. The samples were subsequently analyzed at the Portland Water Bureau Laboratory via EPA Method 200.8, an approved method for the analysis of lead in drinking water.

The EPA recommends follow-up testing if lead concentrations in any sample exceeds 20 parts per billion (ppb) to pinpoint the source(s) of lead contamination in your facility. Steps should be taken to mitigate elevated lead levels. Potential mitigation strategies, as well as sampling protocols, are outlined in the EPA guidance - *3Ts for Reducing Lead in Drinking Water in Schools*.

We encourage you to share these results with the public as soon as possible.

Please let us know if you have any questions on these results or any of the other information provided here.

Sincerely,

Yone Akagi, PE
Water Quality Compliance Manager



**Portland Water Bureau
Laboratory Report**

Water Pollution Control Laboratory

PWB Sample ID	Location Description	Date Collected	Time Collected	Lead (ppb)
BB82434	1st Floor Drinking Fountain - Left	1/20/2017	7:11:00 AM	0.3
BB82435	1st Floor Drinking Fountain - Right	1/20/2017	7:10:00 AM	0.54
BB82436	Lunch Room Sink	1/20/2017	7:09:00 AM	1.51
BB82437	Lunch Room Coffee Maker Hot Tap	1/20/2017	7:08:00 AM	69.5
BB82438	1st Floor Coffee Nook Sink	1/20/2017	7:05:00 AM	1.97
BB82439	2nd Floor Drinking Fountain - Left	1/20/2017	7:15:00 AM	0.44
BB82440	2nd Floor Drinking Fountain - Right	1/20/2017	7:14:00 AM	0.44
BB82441	2nd Floor Coffee Nook Sink	1/20/2017	7:14:00 AM	0.72
BB82442	Bottle Filler at Locker Rooms	1/20/2017	7:03:00 AM	0.1
BB82443	Boathouse Drinking Fountain - Left	1/20/2017	7:02:00 AM	2.54
BB82444	Boathouse Drinking Fountain - Right	1/20/2017	7:01:00 AM	0.71

ppb = parts per billion