



Nick Fish, Commissioner
Michael Stuhr, P.E., Administrator

1120 SW 5th Avenue, Room 600
Portland, Oregon 97204-1926
Information: 503-823-7404
www.portlandoregon.gov/water



March 1, 2017

Jeff Winkler
Sr. Management Analyst
City of Portland - Office of Management and Finance
1120 SW 5th Ave
Portland, OR 97204

RE: Sample Results for 1st & Jefferson Smart Park

Dear Jeff,

Attached you will find the lead results for the water samples collected at the 1st & Jefferson Smart Park between February 7 and 8, 2017. Samples were collected in accordance with the protocol outlined in the EPA Technical Guidance, *3Ts for Reducing Lead in Drinking Water in Schools*. The samples were subsequently analyzed at the Portland Water Bureau Laboratory via EPA Method 200.8, an approved method for the analysis of lead in drinking water.

The EPA recommends follow-up testing if lead concentrations in any sample exceeds 20 parts per billion (ppb) to pinpoint the source(s) of lead contamination in your facility. Steps should be taken to mitigate elevated lead levels. Potential mitigation strategies, as well as sampling protocols, are outlined in the EPA guidance - *3Ts for Reducing Lead in Drinking Water in Schools*.

We encourage you to share these results with the public as soon as possible.

Please let us know if you have any questions on these results or any of the other information provided here.

Sincerely,

Yone Akagi, PE
Water Quality Compliance Manager



**Portland Water Bureau
Laboratory Report**

1st & Jefferson Smart Park

PWB Sample ID	Location Description	Date Collected	Time Collected	Lead (ppb)
BB83324	1234 SW 2nd - Hand Sink	2/7/2017	6:09:00 AM	0.55
BB83325	1234 SW 2nd - Dish Sink	2/7/2017	6:10:00 AM	1.5
BB83326	1216 SW 2nd - South Break Room	2/7/2017	6:41:00 AM	0.85
BB83327	1216 SW 2nd - North Break Room	2/7/2017	6:43:00 AM	0.29
BB83328	1221 SW 1st - Breakroom Sink	2/7/2017	6:22:00 AM	3.12
BB83329	1221 SW 1st - Water Cooler - B	2/7/2017	6:23:00 AM	0.53
BB83330	124 SW Madison - 1st Floor Bre	2/8/2017	6:30:00 AM	0.83
BB83360	1234 SW 2ND - ICE MACHINE	2/7/2017	6:11:00 AM	<0.05

ppb = parts per billion