



Nick Fish, Commissioner
Michael Stuhr, P.E., Administrator



1120 SW 5th Avenue, Room 600
Portland, Oregon 97204-1926
Information: 503-823-7404
www.portlandoregon.gov/water

March 3, 2017

Jeff Winkler
Sr. Management Analyst
City of Portland - Office of Management and Finance
1120 SW 5th Ave
Portland, OR 97204

RE: Sample Results for 10th & Yamhill Smart Park

Dear Jeff,

Attached you will find the lead results for the water samples collected at the 10th & Yamhill Smart Park on February 9 and 15, 2017. Samples were collected in accordance with the protocol outlined in the EPA Technical Guidance, *3Ts for Reducing Lead in Drinking Water in Schools*. The samples were subsequently analyzed at the Portland Water Bureau Laboratory via EPA Method 200.8, an approved method for the analysis of lead in drinking water.

The EPA recommends follow-up testing if lead concentrations in any sample exceeds 20 parts per billion (ppb) to pinpoint the source(s) of lead contamination in your facility. Steps should be taken to mitigate elevated lead levels. Potential mitigation strategies, as well as sampling protocols, are outlined in the EPA guidance - *3Ts for Reducing Lead in Drinking Water in Schools*.

We encourage you to share these results with the public as soon as possible.

Please let us know if you have any questions on these results or any of the other information provided here.

Sincerely,

Yone Akagi, PE
Water Quality Compliance Manager



**Portland Water Bureau
Laboratory Report**

10th & Yamhill Smart Park

PWB Sample ID	Location Description	Date Collected	Time Collected	Lead (ppb)
BB83721	927 SW YAMHILL - BREAK ROOM SINK	2/9/2017	9:31:00 AM	1.8
BB83722	901 SW YAMHILL - OFFICE SINK	2/9/2017	9:28:00 AM	1.36
BB83723	914 SW MORRISON - SINK	2/9/2017	9:33:00 AM	2.39
BB83772	900 SW MORRISON - FOH DISH PREP SINK	2/15/2017	7:36:00 AM	2.03
BB83773	900 SW MORRISON - FOH COUNTER SINK	2/15/2017	7:37:00 AM	0.95
BB83774	900 SW MORRISON - FOH TEA STATION HOT (RIGHT)	2/15/2017	7:35:00 AM	0.67
BB83775	900 SW MORRISON - FOH TEA STATION COLD (LEFT)	2/15/2017	7:35:00 AM	17.2
BB83776	900 SW MORRISON - BOH FOOD PREP RIGHT (1/2)	2/15/2017	7:42:00 AM	1.07
BB83777	900 SW MORRISON - BOH FOOD PREP LEFT (2/2)	2/15/2017	7:43:00 AM	0.48
BB83779	900 SW MORRISON - BOH ISLAND PREP SINK	2/15/2017	7:40:00 AM	3.45
BB83780	900 SW MORRISON - BOH SINGLE PREP SINK	2/15/2017	7:44:00 AM	1.66
BB83781	900 SW MORRISON - ICE MACHINE	2/15/2017	7:46:00 AM	<0.05

ppb = parts per billion