



Nick Fish, Commissioner
Michael Stuhr, P.E., Administrator

1120 SW 5th Avenue, Room 600
Portland, Oregon 97204-1926
Information: 503-823-7404
www.portlandoregon.gov/water



April 24, 2017

Jeff Winkler
Sr. Management Analyst
City of Portland - Office of Management and Finance
1120 SW 5th Ave
Portland, OR 97204

RE: Sample Results for Walnut Park

Dear Jeff,

Attached you will find the lead results for the water samples collected at the Walnut Park on April 5 and 12, 2017. Samples were collected in accordance with the protocol outlined in the EPA Technical Guidance, *3Ts for Reducing Lead in Drinking Water in Schools*. The samples were subsequently analyzed at the Portland Water Bureau Laboratory via EPA Method 200.8, an approved method for the analysis of lead in drinking water.

The EPA recommends follow-up testing if lead concentrations in any sample exceeds 20 parts per billion (ppb) to pinpoint the source(s) of lead contamination in your facility. Steps should be taken to mitigate elevated lead levels. Potential mitigation strategies, as well as sampling protocols, are outlined in the EPA guidance - *3Ts for Reducing Lead in Drinking Water in Schools*.

We encourage you to share these results with the public as soon as possible.

Please let us know if you have any questions on these results or any of the other information provided here.

Sincerely,

Yone Akagi, PE
Water Quality Compliance Manager



**Portland Water Bureau
Laboratory Report**

OR 100014

Walnut Park

PWB Sample ID	Location Description	Date Collected	Time Collected	Lead (ppb)
BB87439	5420 NE 6TH AVE - LAUNDRY ROOM SINK	4/5/2017	7:06:00 AM	0.15
BB87440	418 NE KILLINGSWORTH - WORK ROOM SINK	4/5/2017	10:36:00 AM	1.3
BB87441	446 NE KILLINGSWORTH - BAR SINK 1	4/5/2017	8:08:00 AM	3.99
BB87442	446 NE KILLINGSWORTH - BAR SINK 2	4/5/2017	8:09:00 AM	6.69
BB87443	424 NE KILLINGSWORTH - HALLWAY SINK	4/12/2017	7:37:00 AM	1.64
BB87444	438 NE KILLINGSWORTH - BAR SINK 1	4/5/2017	9:18:00 AM	3.79
BB87445	438 NE KILLINGSWORTH - KITCHEN SINK 1	4/5/2017	9:20:00 AM	0.43
BB87446	438 NE KILLINGSWORTH - KITCHEN SINK 2	4/5/2017	9:21:00 AM	1.36
BB87447	438 NE KILLINGSWORTH - KITCHEN SINK 3	4/5/2017	9:23:00 AM	1.35

ppb = parts per billion