



Nick Fish, Commissioner  
Michael Stuhr, P.E., Administrator

1120 SW 5<sup>th</sup> Avenue, Room 600  
Portland, Oregon 97204-1926  
Information: 503-823-7404  
[www.portlandoregon.gov/water](http://www.portlandoregon.gov/water)



May 5, 2017

Jeff Winkler  
Sr. Management Analyst  
City of Portland - Office of Management and Finance  
1120 SW 5<sup>th</sup> Ave  
Portland, OR 97204

RE: Sample Results for the Kelly Building

Dear Jeff,

Attached you will find the lead results for the water samples collected at the Kelly Building on April 28, 2017. Samples were collected in accordance with the protocol outlined in the EPA Technical Guidance, *3Ts for Reducing Lead in Drinking Water in Schools*. The samples were subsequently analyzed at the Portland Water Bureau Laboratory via EPA Method 200.8, an approved method for the analysis of lead in drinking water.

The EPA recommends follow-up testing if lead concentrations in any sample exceeds 20 parts per billion (ppb) to pinpoint the source(s) of lead contamination in your facility. Steps should be taken to mitigate elevated lead levels. Potential mitigation strategies, as well as sampling protocols, are outlined in the EPA guidance - *3Ts for Reducing Lead in Drinking Water in Schools*.

We encourage you to share these results with the public as soon as possible.

Please let us know if you have any questions on these results or any of the other information provided here.

Sincerely,

Yone Akagi, PE  
Water Quality Compliance Manager



**Portland Water Bureau  
Laboratory Report**

FROM FOREST TO FAUCET OR 100014

**Kelly Building**

<b>PWB Sample ID</b>	<b>Location Description</b>	<b>Date Collected</b>	<b>Time Collected</b>	<b>Lead (ppb)</b>
BB88250	FL1-RM110 ONI BREAK ROOM SINK	4/28/2017	7:00:00 AM	2.96
BB88251	FL1-RM110 ONI BREAK ROOM WATER COOLER COLD TAP	4/28/2017	7:01:00 AM	0.5
BB88252	FL1-RM110 ONI BREAK ROOM WATER COOLER HOT TAP	4/28/2017	7:02:00 AM	0.51
BB88253	FL1-RM100 MCS LOBBY FOUNTAIN-1	4/28/2017	6:42:00 AM	0.92
BB88254	FL1-RM100 MCS LOBBY FOUNTAIN-2	4/28/2017	6:43:00 AM	0.52
BB88255	FL1-RM101A MCS KITCHEN SINK	4/28/2017	6:54:00 AM	2.95
BB88256	FL1-RM113 MCS BREAK ROOM SINK	4/28/2017	6:48:00 AM	0.81
BB88257	FL1-RM113 MCS BREAK ROOM FOUNTAIN	4/28/2017	6:50:00 AM	0.29
BB88258	FL1-RM113 MCS BREAK ROOM BOTTLE FILLER	4/28/2017	6:51:00 AM	0.29
BB88259	FL1-RMC106 MCS HALL KITCHENETTE SINK	4/28/2017	6:36:00 AM	0.8
BB88260	FL1-RMC106 MCS HALL KITCHENETTE HOT TAP	4/28/2017	6:38:00 AM	1.19
BB88261	FLB-GARAGE CITY FLEET FOUNTAIN	4/28/2017	6:30:00 AM	3.09

ppb = parts per billion