



Nick Fish, Commissioner
Michael Stuhr, P.E., Administrator

1120 SW 5th Avenue, Room 600
Portland, Oregon 97204-1926
Information: 503-823-7404
www.portlandoregon.gov/water



June 15, 2017

Chris Silkie, PE, LEED AP, CEM
Asset Management Program Manager
Portland Parks & Recreation
6437 SE Division St, Suite 416
Portland, OR 97206

RE: Sample Result for Portland International Raceway

Dear Chris,

Attached you will find the lead result for the water sample collected at Portland International Raceway on May 22, 2017. The sample was collected in accordance with the protocol outlined in the EPA Technical Guidance, *3Ts for Reducing Lead in Drinking Water in Schools*. The sample was subsequently analyzed at the Portland Water Bureau Laboratory via EPA Method 200.8, an approved method for the analysis of lead in drinking water.

The EPA recommends follow-up testing if lead concentrations in any sample exceeds 20 parts per billion (ppb) to pinpoint the source(s) of lead contamination in your facility. Steps should be taken to mitigate elevated lead levels. Potential mitigation strategies, as well as sampling protocols, are outlined in the EPA guidance - *3Ts for Reducing Lead in Drinking Water in Schools*.

We encourage you to share these results with the public as soon as possible.

Please let us know if you have any questions on these results or any of the other information provided here.

Sincerely,

Yone Akagi, P.E.
Water Quality Manager
Portland Water Bureau



**Portland Water Bureau
Laboratory Report**

FROM FOREST TO FAUCET OR 100014

Portland International Raceway

PWB Sample ID	Location Description	Date Collected	Time Collected	Lead (ppb)
BB89339	FAST TRACK CONCESSION 1-OUT-SINK-1	5/22/2017	8:58:00 AM	2.18
BB89340	FAST TRACK CONCESSION 1-OUT-HB-1	5/22/2017	9:00:00 AM	2.88
BB89341	FAST TRACK CONCESSION 1-OUT-HB-2	5/22/2017	9:03:00 AM	0.54
BB89342	FAST TRACK CONCESSION 1-103-IM-1	5/22/2017	9:08:00 AM	0.094
BB89343	FAST TRACK CONCESSION 1-104-SINK-1	5/22/2017	9:06:00 AM	2.11
BB89344	FAST TRACK CONCESSION 1-104-SINK-2	5/22/2017	9:07:00 AM	5.3
BB89345	WEST OF FAST TRACK CONCESSION 1-OUT-HB-3	5/22/2017	9:11:00 AM	1.52
BB89346	NORTH RESTROOM 1-OUT-HB-4	5/22/2017	9:20:00 AM	6.45
BB89347	NORTH RESTROOM 1-OUT-HB-5	5/22/2017	9:21:00 AM	2.94
BB89348	MAIN OFFICE 3-301-SINK-1	5/22/2017	8:55:00 AM	5.54
BB89349	MOTO CROSS CONCESSION 1-103-IM-1	5/22/2017	9:28:00 AM	0.13
BB89350	MOTO CROSS CONCESSION 1-104-SINK-1	5/22/2017	9:25:00 AM	60.2
BB89351	MOTO CROSS CONCESSION 1-104-SINK-2	5/22/2017	9:26:00 AM	33.1
BB89387	BEHIND BEACHES 1-OUT-HB-6	5/22/2017	9:15:00 AM	6.74

ppb = parts per billion



Nick Fish, Commissioner
Michael Stuhr, P.E., Administrator

1120 SW 5th Avenue, Room 600
Portland, Oregon 97204-1926
Information: 503-823-7404
www.portlandoregon.gov/water



October 4, 2017

Chris Silkie, PE, LEED AP, CEM
Asset Management Program Manager
Portland Parks & Recreation
6437 SE Division St, Suite 416
Portland, OR 97206

RE: Post-remediation Sample Results for Portland International Raceway

Dear Chris,

Attached you will find the post-remediation lead results for the water samples collected at Portland International Raceway on September 25, 2017. The samples were collected in accordance with the protocol outlined in the EPA Technical Guidance, *3Ts for Reducing Lead in Drinking Water in Schools*. The samples were subsequently analyzed at the Portland Water Bureau Laboratory via EPA Method 200.8, an approved method for the analysis of lead in drinking water.

The EPA recommends follow-up testing if lead concentrations in any sample exceeds 20 parts per billion (ppb) to pinpoint the source(s) of lead contamination in your facility. Steps should be taken to mitigate elevated lead levels. Potential mitigation strategies, as well as sampling protocols, are outlined in the EPA guidance - *3Ts for Reducing Lead in Drinking Water in Schools*.

We encourage you to share these results with the public as soon as possible.

Please let us know if you have any questions on these results or any of the other information provided here.

Sincerely,

Yone Akagi, P.E.
Water Quality Manager
Portland Water Bureau



**Portland Water Bureau
Laboratory Report**

Portland International Raceway (Post-remediation)

PWB Sample ID	Location Description	Date Collected	Time Collected	Lead (ppb)
BB94722	MOTO CROSS CONCESSION 1-104-SINK-1	9/25/2017	7:11:00 AM	15.4
BB94723	MOTO CROSS CONCESSION 1-104-SINK-2	9/25/2017	7:11:00 AM	89.8

ppb = parts per billion