

Nick Fish, Commissioner Michael Stuhr, P.E., Administrator

1120 SW 5th Avenue, Room 600 Portland, Oregon 97204-1926 Information: 503-823-7404 www.portlandoregon.gov/water



July 10, 2017

Chris Silkie, PE, LEED AP, CEM
Asset Management Program Manager
Portland Parks & Recreation
6437 SE Division St, Suite 416
Portland, OR 97206

RE: Sample Results for Lan Su Chinese Garden

Dear Chris,

Attached you will find the lead results for the water samples collected at Lan Su Chinese Garden on June 30, 2017. The samples were collected in accordance with the protocol outlined in the EPA Technical Guidance, 3Ts for Reducing Lead in Drinking Water in Schools. The samples were subsequently analyzed at the Portland Water Bureau Laboratory via EPA Method 200.8, an approved method for the analysis of lead in drinking water.

The EPA recommends follow-up testing if lead concentrations in any sample exceeds 20 parts per billion (ppb) to pinpoint the source(s) of lead contamination in your facility. Steps should be taken to mitigate elevated lead levels. Potential mitigation strategies, as well as sampling protocols, are outlined in the EPA guidance - 3Ts for Reducing Lead in Drinking Water in Schools.

We encourage you to share these results with the public as soon as possible.

Please let us know if you have any questions on these results or any of the other information provided here.

Sincerely,

Yone Akagi, P.E.

Water Quality Manager

Portland Water Bureau



Lan Su Chinese Garden

PWB		Date	Time	Lead
Sample ID	Location Description	Collected	Collected	(ppb)
BB91193	GARDEN WATER STATION DRINKING FOUNTAIN - HIGH	6/30/2017	7:57:00 AM	3.47
BB91194	GARDEN WATER STATION DRINKING FOUNTAIN - LOW	6/30/2017	7:58:00 AM	0.95
BB91195	GARDEN WATER STATION DRINKING FOUNTAIN - BOTTLE FILLER	6/30/2017	7:59:00 AM	0.53
BB91196	TEA HOUSE SINK	6/30/2017	8:01:00 AM	0.15
BB91197	TEA HOUSE HOT WATER DISPENSER	6/30/2017	8:04:00 AM	0.55
BB91232	TEA HOUSE BOTTLE FILLER	6/30/2017	8:02:00 AM	0.23

ppb = parts per billion