



Nick Fish, Commissioner
Michael Stuhr, P.E., Administrator

1120 SW 5th Avenue, Room 600
Portland, Oregon 97204-1926
Information: 503-823-7404
www.portlandoregon.gov/water



August 17, 2017

Jeff Winkler
Sr. Management Analyst
City of Portland - Office of Management and Finance
1120 SW 5th Ave
Portland, OR 97204

RE: Post-remediation Sample Results for Union Station

Dear Jeff,

Attached you will find the lead results for the post-remediation water samples collected at Union Station on August 4, 2017. Samples were collected in accordance with the protocol outlined in the EPA Technical Guidance, *3Ts for Reducing Lead in Drinking Water in Schools*. The samples were subsequently analyzed at the Portland Water Bureau Laboratory via EPA Method 200.8, an approved method for the analysis of lead in drinking water.

The lead results from these samples are intended to confirm that remediation was effective at reducing lead in water in your facility. The EPA recommends further actions to reduce lead in water if lead concentrations in any sample exceeds 20 parts per billion (ppb). Potential mitigation strategies, as well as sampling protocols, are outlined in the EPA guidance - *3Ts for Reducing Lead in Drinking Water in Schools*.

We encourage you to share these results with the public as soon as possible.

Please let us know if you have any questions on these results or any of the other information provided here.

Sincerely,

Yone Akagi, P.E.
Water Quality Manager
Portland Water Bureau



**Portland Water Bureau
Laboratory Report**

OR 100014

Union Station - Post-remediation

PWB Sample ID	Location Description	Date Collected	Time Collected	Lead (ppb)
BB92551	Room 200A Annex Sink	8/4/2017	7:24:00 AM	6.47
BB92552	Room 250A Annex Sink	8/4/2017	7:22:00 AM	11.1

ppb = parts per billion