



Nick Fish, Commissioner  
Michael Stuhr, P.E., Administrator

1120 SW 5<sup>th</sup> Avenue, Room 600  
Portland, Oregon 97204-1926  
Information: 503-823-7404  
[www.portlandoregon.gov/water](http://www.portlandoregon.gov/water)



August 17, 2017

Chris Silkie, PE, LEED AP, CEM  
Asset Management Program Manager  
Portland Parks & Recreation  
6437 SE Division St, Suite 416  
Portland, OR 97206

RE: Sample Results for Erv Lind Stadium

Dear Chris,

Attached you will find the lead results for the water samples collected at Erv Lind Stadium on August 2, 2017. The samples were collected in accordance with the protocol outlined in the EPA Technical Guidance, *3Ts for Reducing Lead in Drinking Water in Schools*. The samples were subsequently analyzed at the Portland Water Bureau Laboratory via EPA Method 200.8, an approved method for the analysis of lead in drinking water.

The EPA recommends follow-up testing if lead concentrations in any sample exceeds 20 parts per billion (ppb) to pinpoint the source(s) of lead contamination in your facility. Steps should be taken to mitigate elevated lead levels. Potential mitigation strategies, as well as sampling protocols, are outlined in the EPA guidance - *3Ts for Reducing Lead in Drinking Water in Schools*.

We encourage you to share these results with the public as soon as possible.

Please let us know if you have any questions on these results or any of the other information provided here.

Sincerely,

Yone Akagi, P.E.  
Water Quality Manager  
Portland Water Bureau



**Portland Water Bureau  
Laboratory Report**

OR 100014

**Erv Lind Stadium**

<b>PWB Sample ID</b>	<b>Location Description</b>	<b>Date Collected</b>	<b>Time Collected</b>	<b>Lead (ppb)</b>
BB92436	SINK-1 CONCESSIONS 3 BASIN	8/2/2017	7:30:00 AM	49.8
BB92437	SINK-2 CONCESSIONS SMALL HAND WASH	8/2/2017	7:32:00 AM	19.5
BB92438	0444-DF-4	8/2/2017	7:35:00 AM	0.88

ppb = parts per billion



Nick Fish, Commissioner  
Michael Stuhr, P.E., Administrator

1120 SW 5<sup>th</sup> Avenue, Room 600  
Portland, Oregon 97204-1926  
Information: 503-823-7404  
[www.portlandoregon.gov/water](http://www.portlandoregon.gov/water)



September 12, 2017

Chris Silkie, PE, LEED AP, CEM  
Asset Management Program Manager  
Portland Parks & Recreation  
6437 SE Division St, Suite 416  
Portland, OR 97206

RE: Follow-up Sample Results for Irv Lind Stadium

Dear Chris,

Attached you will find the lead results for the follow-up water samples collected at Irv Lind Stadium on August 29, 2017. Samples were collected based on protocols outlined in the EPA Technical Guidance, *3Ts for Reducing Lead in Drinking Water in Schools*. The samples were subsequently analyzed at the Portland Water Bureau Laboratory via EPA Method 200.8, an approved method for the analysis of lead in drinking water.

The lead results from these follow-up samples are intended to provide additional information on the possible source(s) which are contributing lead to water in your facility. Information on the interpretation of these results, as well as possible mitigation strategies, are outlined in the EPA guidance – *3Ts for Reducing Lead in Drinking Water in Schools*.

We encourage you to share these results with the public as soon as possible.

Please let us know if you have any questions on these results or any of the other information provided here.

Sincerely,

Yone Akagi, P.E.  
Water Quality Manager  
Portland Water Bureau



**Portland Water Bureau  
Laboratory Report**

OR 100014

**Erv Lind Stadium**

<b>PWB Sample ID</b>	<b>Location Description</b>	<b>Date Collected</b>	<b>Time Collected</b>	<b>Lead Result (ppb)</b>	<b>Sample Type</b>
BB93650	SINK-1 CONCESSIONS 3 BASIN- 125ml FAUCET	8/29/2017	7:00:00 AM	9.45	First Draw Sample #1 - 125mL
BB93651	SINK-1 CONCESSIONS 3 BASIN- 125ml PIPE	8/29/2017	7:01:00 AM	9.23	First Draw Sample #2 - 125mL
BB93652	SINK-1 CONCESSIONS 3 BASIN- 250ml RUNNING	8/29/2017	7:02:00 AM	2.58	30 Second Flowing Sample
BB93653	SINK-2 CONCESSIONS SMALL HAND WASH - 125ml FAUCET	8/29/2017	7:04:00 AM	9.72	First Draw Sample #1 - 125mL
BB93654	SINK-2 CONCESSIONS SMALL HAND WASH - 125ml PIPE	8/29/2017	7:05:00 AM	6.76	First Draw Sample #2 - 125mL
BB93655	SINK-2 CONCESSIONS SMALL HAND WASH - 250ml RUNNING	8/29/2017	7:06:00 AM	2.85	30 Second Flowing Sample

ppb = parts per billion