



Nick Fish, Commissioner
Michael Stuhr, P.E., Administrator

1120 SW 5th Avenue, Room 600
Portland, Oregon 97204-1926
Information: 503-823-7404
www.portlandoregon.gov/water



November 8, 2017

Don De Piero
Vehicle Maintenance Superintendent
Office of Management & Finance
2835 N Kerby Ave
Portland, OR 97227

RE: Sample Results for Kerby Garage

Dear Don,

Attached you will find the lead results for the water samples collected at the Kerby Garage on October 23 and 24, 2017. The samples were collected in accordance with the protocol outlined in the EPA Technical Guidance, *3Ts for Reducing Lead in Drinking Water in Schools*. The samples were subsequently analyzed at the Portland Water Bureau Laboratory via EPA Method 200.8, an approved method for the analysis of lead in drinking water.

The EPA recommends follow-up testing if lead concentrations in any sample exceeds 20 parts per billion (ppb) to pinpoint the source(s) of lead contamination in your facility. Steps should be taken to mitigate elevated lead levels. Potential mitigation strategies, as well as sampling protocols, are outlined in the EPA guidance - *3Ts for Reducing Lead in Drinking Water in Schools*.

We encourage you to share these results with the public as soon as possible.

Please let us know if you have any questions on these results or any of the other information provided here.

Sincerely,

Yone Akagi, P.E.
Water Quality Manager
Portland Water Bureau



**Portland Water Bureau
Laboratory Report**

OR 100014

Kerby Garage

PWB Sample ID	Location Description	Date Collected	Time Collected	Lead (ppb)
BB96270	Office - DF Left	10/23/2017	5:32:00 AM	0.57
BB96271	Office - DF Right	10/23/2017	5:32:00 AM	0.56
BB96272	Office - Kitchen Sink	10/23/2017	5:34:00 AM	5.84
BB96273	Lunch Room Sink	10/23/2017	5:36:00 AM	2.41
BB96274	Lunch Room Water Cooler	10/23/2017	5:37:00 AM	0.25
BB96275	Parts Department DF	10/23/2017	5:39:00 AM	1.67
BB96276	Parts Department DF - Bottle Filler	10/23/2017	5:40:00 AM	4.66
BB96277	Upper Lvl Motorcycle Bay - DF	10/23/2017	5:42:00 AM	5.45
BB96278	Upper Lvl West DF	10/23/2017	5:44:00 AM	5
BB96279	Lower Lvl Fabrication Area DF	10/23/2017	5:45:00 AM	5.17
BB96280	Lower Lvl Bay 45 DF	10/23/2017	5:47:00 AM	4.32
BB96281	Lower Lvl DF Between Office and Bay Door	10/23/2017	5:48:00 AM	20.1
BB96282	Egress Passage DF	10/23/2017	5:49:00 AM	1.26
BB96283	Basement - Signal Shop Kitchen Sink	10/23/2017	6:10:00 AM	3.69
BB96284	Basement - DF Outside Meter Shop	10/23/2017	6:11:00 AM	1.7
BB96285	Basement - Bottle Filler on DF Outside Meter Shop	10/23/2017	6:11:00 AM	2.91
BB96286	Basement - North Loading Bay DF	10/23/2017	6:03:00 AM	1.98
BB96288	Basement - Gym DF - Left	10/23/2017	6:05:00 AM	0.46
BB96289	Basement - Gym DF - Right	10/23/2017	6:05:00 AM	0.51
BB96290	Basement - Gym DF - Bottle Filler	10/23/2017	6:05:00 AM	0.5
BB96425	Basement - Sign Shop Sink	10/24/2017	6:45:00 AM	19.4

ppb = parts per billion