



Nick Fish, Commissioner
Michael Stuhr, P.E., Administrator



1120 SW 5th Avenue, Room 600
Portland, Oregon 97204-1926
Information: 503-823-7404
www.portlandoregon.gov/water

January 9, 2018

Jeff Winkler
Sr. Management Analyst
City of Portland - Office of Management and Finance
1120 SW 5th Ave
Portland, OR 97204

RE: Sample Results for Naito & Davis Smart Park

Dear Jeff,

Attached you will find the lead results for the water samples collected at the Naito & Davis Smart Park on December 21, 2017. The samples were collected in accordance with the protocol outlined in the EPA Technical Guidance, *3Ts for Reducing Lead in Drinking Water in Schools*. The samples were subsequently analyzed at the Portland Water Bureau Laboratory via EPA Method 200.8, an approved method for the analysis of lead in drinking water.

The EPA recommends follow-up testing if lead concentrations in any sample exceeds 20 parts per billion (ppb) to pinpoint the source(s) of lead contamination in your facility. Steps should be taken to mitigate elevated lead levels. Potential mitigation strategies, as well as sampling protocols, are outlined in the EPA guidance - *3Ts for Reducing Lead in Drinking Water in Schools*.

We encourage you to share these results with the public as soon as possible.

Please let us know if you have any questions on these results or any of the other information provided here.

Sincerely,

Yone Akagi, P.E.
Water Quality Manager
Portland Water Bureau



**Portland Water Bureau
Laboratory Report**

OR 100014

Naito & Davis Smart Park

PWB Sample ID	Location Description	Date Collected	Time Collected	Lead (ppb)
BB99096	Portland Police Kitchenette Sink	12/21/2017	8:00:00 AM	0.77
BB99097	Access Hallway Drinking Fountain	12/21/2017	8:02:00 AM	1.13
BB99098	Portland Patrol Break Room Sink	12/21/2017	8:04:00 AM	0.88
BB99099	Portland Patrol Water Cooler	12/21/2017	8:05:00 AM	0.063
BB99100	Transit Police Water Cooler	12/21/2017	8:07:00 AM	0.13
BB99101	Transit Police Holding Cell 1 Sink	12/21/2017	8:10:00 AM	21.2
BB99102	Transit Police Holding Cell 2 Sink	12/21/2017	8:09:00 AM	5.39
BB99103	Transit Police Break Room Sink	12/21/2017	8:12:00 AM	0.91

ppb = parts per billion