



Nick Fish, Commissioner
Michael Stuhr, P.E., Administrator

1120 SW 5th Avenue, Room 600
Portland, Oregon 97204-1926
Information: 503-823-7404
www.portlandoregon.gov/water



February 16, 2018

Jeff Winkler
Sr. Management Analyst
City of Portland - Office of Management and Finance
1120 SW 5th Ave
Portland, OR 97204

RE: Sample Results for Guilds Lake Property Warehouse

Dear Jeff,

Attached you will find the lead results for the water samples collected at Guilds Lake Property Warehouse on January 30, 2018. The samples were collected in accordance with the protocol outlined in the EPA Technical Guidance, *3Ts for Reducing Lead in Drinking Water in Schools*. The samples were subsequently analyzed at the Portland Water Bureau Laboratory via EPA Method 200.8, an approved method for the analysis of lead in drinking water.

The EPA recommends follow-up testing if lead concentrations in any sample exceeds 20 parts per billion (ppb) to pinpoint the source(s) of lead contamination in your facility. Steps should be taken to mitigate elevated lead levels. Potential mitigation strategies, as well as sampling protocols, are outlined in the EPA guidance - *3Ts for Reducing Lead in Drinking Water in Schools*.

We encourage you to share these results with the public as soon as possible.

Please let us know if you have any questions on these results or any of the other information provided here.

Sincerely,

Yone Akagi, P.E.
Water Quality Manager
Portland Water Bureau



**Portland Water Bureau
Laboratory Report**

OR 100014

Guilds Lake Property Warehouse

PWB Sample ID	Location Description	Date Collected	Time Collected	Lead (ppb)
BC01056	HALLWAY DRINKING FOUNTAIN	1/30/2018	7:15:00 AM	0.32
BC01057	HALLWAY BOTTLE FILL	1/30/2018	7:16:00 AM	0.28
BC01058	BREAKROOM SINK	1/30/2018	7:18:00 AM	1.51

ppb = parts per billion