



Nick Fish, Commissioner
Michael Stuhr, P.E., Administrator

1120 SW 5th Avenue, Room 600
Portland, Oregon 97204-1926
Information: 503-823-7404
www.portlandoregon.gov/water



November 21, 2017

Shawn Roberti
Sr. Facilities Maintenance Supervisor
Portland Fire and Rescue
1135 SE Powell Blvd
Portland, OR 97214

RE: Additional Sample Result for Station 21

Dear Shawn,

Attached you will find the lead result for the water sample collected at Stations 21 on June 16, 2017. This sample was received by the Portland Water Bureau on November 9, 2017. Samples were collected in accordance with the protocol outlined in the EPA Technical Guidance, *3Ts for Reducing Lead in Drinking Water in Schools*. The sample was subsequently analyzed at the Portland Water Bureau Laboratory via EPA Method 200.8, an approved method for the analysis of lead in drinking water.

The EPA recommends follow-up testing if lead concentrations in any sample exceeds 20 parts per billion (ppb) to pinpoint the source(s) of lead contamination in your facility. Steps should be taken to mitigate elevated lead levels. Potential mitigation strategies, as well as sampling protocols, are outlined in the EPA guidance - *3Ts for Reducing Lead in Drinking Water in Schools*.

We encourage you to share this result with the public as soon as possible.

Please let us know if you have any questions on this result or any of the other information provided here.

Sincerely,

Yone Akagi, P.E.
Water Quality Manager
Portland Water Bureau



**Portland Water Bureau
Laboratory Report**
OR 100014

Station 21 - Additional Sample

PWB Sample ID	Location Description	Date Collected	Time Collected	Lead (ppb)
BB97160	KITCHEN SINK RIGHT	6/16/2017	7:18:00 AM	0.064

ppb = parts per billion