



Nick Fish, Commissioner
Michael Stuhr, P.E., Administrator

1120 SW 5th Avenue, Room 600
Portland, Oregon 97204-1926
Information: 503-823-7404
www.portlandoregon.gov/water



August 17, 2017

Tom Klutz
Property Acquisition & Services Manager
Portland Water Bureau
1120 SW 5th Ave
Portland, OR 97204

RE: Sample Results for Dodge Park

Dear Tom,

Attached you will find the lead results for the water samples collected at Dodge Park on July 31, 2017. Samples were collected in accordance with the protocol outlined in the EPA Technical Guidance, *3Ts for Reducing Lead in Drinking Water in Schools*. The samples were subsequently analyzed at the Portland Water Bureau Laboratory via EPA Method 200.8, an approved method for the analysis of lead in drinking water.

The EPA recommends follow-up testing if lead concentrations in any sample exceeds 20 parts per billion (ppb) to pinpoint the source(s) of lead contamination in your facility. Steps should be taken to mitigate elevated lead levels. Potential mitigation strategies, as well as sampling protocols, are outlined in the EPA guidance - *3Ts for Reducing Lead in Drinking Water in Schools*.

We encourage you to share these results with the public as soon as possible.

Please let us know if you have any questions on these results or any of the other information provided here.

Sincerely,

Yone Akagi, P.E.
Water Quality Manager
Portland Water Bureau



**Portland Water Bureau
Laboratory Report**

OR 100014

Dodge Park

PWB Sample ID	Location Description	Date Collected	Time Collected	Lead (ppb)
BB92348	CAMP HOST WATER SUPPLY	7/31/2017	7:00:00 AM	7.39
BB92349	POTABLE WATER SOURCE	7/31/2017	6:55:00 AM	3.93
BB92350	KITCHEN SINK	7/31/2017	6:58:00 AM	0.67

ppb = parts per billion