



Nick Fish, Commissioner
Michael Stuhr, P.E., Administrator

1120 SW 5th Avenue, Room 600
Portland, Oregon 97204-1926
Information: 503-823-7404
www.portlandoregon.gov/water



April 25, 2018

Jeff Winkler
Sr. Management Analyst
City of Portland - Office of Management and Finance
1120 SW 5th Ave
Portland, OR 97204

RE: Sample Results for the Portland Police Bureau's St. Johns Traffic Division Building

Dear Jeff,

Attached you will find the lead results for the water samples collected at the Portland Police Bureau's St. Johns Traffic Division Building on April 11, 2018. The samples were collected in accordance with the protocol outlined in the EPA Technical Guidance, *3Ts for Reducing Lead in Drinking Water in Schools*. The samples were subsequently analyzed at the Portland Water Bureau Laboratory via EPA Method 200.8, an approved method for the analysis of lead in drinking water.

The EPA recommends follow-up testing if lead concentrations in any sample exceeds 20 parts per billion (ppb) to pinpoint the source(s) of lead contamination in your facility. Steps should be taken to mitigate elevated lead levels. Potential mitigation strategies, as well as sampling protocols, are outlined in the EPA guidance - *3Ts for Reducing Lead in Drinking Water in Schools*.

We encourage you to share these results with the public as soon as possible.

Please let us know if you have any questions on these results or any of the other information provided here.

Sincerely,

Yone Akagi, P.E.
Water Quality Manager
Portland Water Bureau



**Portland Water Bureau
Laboratory Report**

Portland Police Bureau's St. Johns Traffic Division Building

PWB Sample ID	Location Description	Date Collected	Time Collected	Lead (ppb)
BC04438	MAIN ENTRY DRINKING FOUNTAIN	4/11/2018	7:28:00 AM	<0.05
BC04439	MAIN ENTRY BOTTLE FILL	4/11/2018	7:29:00 AM	<0.05
BC04440	MAIN FLOOR KITCHENETTE SINK	4/11/2018	7:31:00 AM	0.49
BC04441	MAIN FLOOR KITCHENETTE INSTA HOT	4/11/2018	7:32:00 AM	0.15
BC04442	BASEMENT DRINKING FOUNTIAN LEFT	4/11/2018	7:34:00 AM	0.62
BC04443	BASEMENT DRINKING FOUNTIAN RIGHT	4/11/2018	7:35:00 AM	0.73
BC04444	SECOND FLOOR KITCHENETTE SINK	4/11/2018	7:38:00 AM	0.54
BC04445	SECOND FLOOR KITCHENETTE INSTA HOT	4/11/2018	7:39:00 AM	2.33
BC04446	SECOND FLOOR LANDING DRINKING FOUNTAIN LEFT	4/11/2018	7:41:00 AM	0.41
BC04447	SECOND FLOOR LANDING DRINKING FOUNTAIN RIGHT	4/11/2018	7:42:00 AM	0.24

ppb = parts per billion

