



Nick Fish, Commissioner  
Michael Stuhr, P.E., Administrator



1120 SW 5<sup>th</sup> Avenue, Room 600  
Portland, Oregon 97204-1926  
Information: 503-823-7404  
[www.portlandoregon.gov/water](http://www.portlandoregon.gov/water)

July 1, 2018

Tom Klutz  
Property Acquisition & Services Manager  
Portland Water Bureau  
1120 SW 5<sup>th</sup> Ave  
Portland, OR 97204

RE: Sample Results for the Groundwater Pump Station

Dear Tom,

Attached you will find the lead results for the water samples collected at the Groundwater Pump Station on May 10, 2018. The samples were subsequently analyzed at the Portland Water Bureau Laboratory via EPA Method 200.8, an approved method for the analysis of lead in drinking water.

The EPA recommends follow-up testing if lead concentrations in any sample exceeds 20 parts per billion (ppb) to pinpoint the source(s) of lead contamination in your facility. Steps should be taken to mitigate elevated lead levels. Potential mitigation strategies, as well as sampling protocols, are outlined in the EPA guidance - *3Ts for Reducing Lead in Drinking Water in Schools*.

We encourage you to share these results with the public as soon as possible.

Please let us know if you have any questions on these results or any of the other information provided here.

Sincerely,

Yone Akagi, P.E.  
Water Quality Manager  
Portland Water Bureau



**Portland Water Bureau**  
**Laboratory Report**  
OR 100014

**Groundwater Pump Station**

<b>PWB Sample ID</b>	<b>Location Description</b>	<b>Date Collected</b>	<b>Time Collected</b>	<b>Lead (ppb)</b>
BC05977	KITCHENETTE SINK	5/10/2018	8:30:00 AM	2.98
BC05978	DRINKING FOUNTAIN	5/10/2018	8:30:00 AM	0.82

ppb = parts per billion