



Nick Fish, Commissioner
Michael Stuhr, P.E., Administrator

1120 SW 5th Avenue, Room 600
Portland, Oregon 97204-1926
Information: 503-823-7404
www.portlandoregon.gov/water



July 1, 2018

Tom Klutz
Property Acquisition & Services Manager
Portland Water Bureau
1120 SW 5th Ave
Portland, OR 97204

RE: Sample Results for the Sandy River Station, Lusted Hill & Headworks Facilities

Dear Tom,

Attached you will find the lead results for the water samples collected at Sandy River Station, Lusted Hill & Headworks Facilities on May 15 and 17, 2018. The samples were subsequently analyzed at the Portland Water Bureau Laboratory via EPA Method 200.8, an approved method for the analysis of lead in drinking water.

The EPA recommends follow-up testing if lead concentrations in any sample exceeds 20 parts per billion (ppb) to pinpoint the source(s) of lead contamination in your facility. Steps should be taken to mitigate elevated lead levels. Potential mitigation strategies, as well as sampling protocols, are outlined in the EPA guidance - *3Ts for Reducing Lead in Drinking Water in Schools*.

We encourage you to share these results with the public as soon as possible.

Please let us know if you have any questions on these results or any of the other information provided here.

Sincerely,

Yone Akagi, P.E.
Water Quality Manager
Portland Water Bureau



**Portland Water Bureau
Laboratory Report**
OR 100014

Sandy River Station, Lusted Hill & Headworks Facilities

PWB Sample ID	Location Description	Date Collected	Time Collected	Lead (ppb)
BC06053	LUSTED HILL - BREAKROOM SINK	5/15/2018	6:10:00 AM	0.11
BC06054	LUSTED HILL - LAB SINK	5/15/2018	6:08:00 AM	9.8
BC06055	HEADWORKS - KITCHENETTE SINK	5/15/2018	7:11:00 AM	1.47
BC06056	HEADWORKS - KITCHENETTE BOTTLE FILL	5/15/2018	7:11:00 AM	12.9
BC06154	HEADWORKS - OUTSIDE BUBBLER	5/15/2018	9:15:00 AM	0.29
BC06267	SANDY RIVER STATION - KITCHEN - SINK	5/17/2018	5:44:00 AM	0.42
BC06268	SANDY RIVER STATION - KITCHEN - DRINKNG FOUNTAIN	5/17/2018	5:42:00 AM	6.32
BC06269	SANDY RIVER STATION - KITCHEN - COFFEE MAKER HOT WATER TAP	5/17/2018	5:40:00 AM	5.73

ppb = parts per billion