



Nick Fish, Commissioner  
Michael Stuhr, P.E., Administrator

1120 SW 5<sup>th</sup> Avenue, Room 600  
Portland, Oregon 97204-1926  
Information: 503-823-7404  
[www.portlandoregon.gov/water](http://www.portlandoregon.gov/water)



July 1, 2018

Jill Jacobsen  
Program Manager  
Portland Bureau of Transportation  
2929 N Kerby St  
Portland, OR 97227

RE: Sample Results for the Valvoline Building

Dear Jill,

Attached you will find the lead results for the water samples collected at the Valvoline Building on June 14, 2018. Samples were collected in accordance with the protocol outlined in the EPA Technical Guidance, *3Ts for Reducing Lead in Drinking Water in Schools*. The samples were subsequently analyzed at the Portland Water Bureau Laboratory via EPA Method 200.8, an approved method for the analysis of lead in drinking water.

The EPA recommends follow-up testing if lead concentrations in any sample exceeds 20 parts per billion (ppb) to pinpoint the source(s) of lead contamination in your facility. Steps should be taken to mitigate elevated lead levels. Potential mitigation strategies, as well as sampling protocols, are outlined in the EPA guidance - *3Ts for Reducing Lead in Drinking Water in Schools*.

We encourage you to share these results with the public as soon as possible.

Please let us know if you have any questions on these results or any of the other information provided here.

Sincerely,

Yone Akagi, P.E.  
Water Quality Manager  
Portland Water Bureau



**Portland Water Bureau  
Laboratory Report**  
OR 100014

**Valvoline Building**

| <b>PWB<br/>Sample ID</b> | <b>Location Description</b> | <b>Date<br/>Collected</b> | <b>Time<br/>Collected</b> | <b>Lead<br/>(ppb)</b> |
|--------------------------|-----------------------------|---------------------------|---------------------------|-----------------------|
| BC07397                  | FL2 - KITCHEN SINK          | 6/14/2018                 | 7:34:00 AM                | 37                    |

ppb = parts per billion