



Nick Fish, Commissioner  
Michael Stuhr, P.E., Administrator

1120 SW 5<sup>th</sup> Avenue, Room 600  
Portland, Oregon 97204-1926  
Information: 503-823-7404  
[www.portlandoregon.gov/water](http://www.portlandoregon.gov/water)



July 1, 2018

Tom Klutz  
Property Acquisition & Services Manager  
Portland Water Bureau  
1120 SW 5<sup>th</sup> Ave  
Portland, OR 97204

RE: Sample Results for the Interstate Facility

Dear Tom,

Attached you will find the lead results for the water samples collected at the Interstate Facility between May 11 and June 1, 2018. The samples were subsequently analyzed at the Portland Water Bureau Laboratory via EPA Method 200.8, an approved method for the analysis of lead in drinking water.

The EPA recommends follow-up testing if lead concentrations in any sample exceeds 20 parts per billion (ppb) to pinpoint the source(s) of lead contamination in your facility. Steps should be taken to mitigate elevated lead levels. Potential mitigation strategies, as well as sampling protocols, are outlined in the EPA guidance - *3Ts for Reducing Lead in Drinking Water in Schools*.

We encourage you to share these results with the public as soon as possible.

Please let us know if you have any questions on these results or any of the other information provided here.

Sincerely,

Yone Akagi, P.E.  
Water Quality Manager  
Portland Water Bureau



**Portland Water Bureau**  
**Laboratory Report**  
 OR 100014

**Interstate Facility**

<b>PWB Sample ID</b>	<b>Location Description</b>	<b>Date Collected</b>	<b>Time Collected</b>	<b>Lead (ppb)</b>
BC05947	WAREHOUSE - LUNCH ROOM - DRINKING FOUNTAIN LEFT	5/11/2018	6:50:00 AM	0.05
BC05948	WAREHOUSE - LUNCH ROOM - DRINKING FOUNTAIN RIGHT	5/11/2018	6:50:00 AM	<0.05
BC05949	WAREHOUSE - LUNCH ROOM - BOTTLE FILL	5/11/2018	6:51:00 AM	<0.05
BC05950	WAREHOUSE - LUNCH ROOM - SINK	5/11/2018	6:53:00 AM	0.22
BC05951	WAREHOUSE - LUNCH ROOM - INSTA HOT	5/11/2018	6:53:00 AM	0.27
BC05952	WAREHOUSE - LUNCH ROOM - COFFEE MAKER HOT WATER TAP	5/11/2018	6:54:00 AM	0.13
BC05953	WAREHOUSE - TOOL ROOM - DRINKING FOUNTAIN LEFT	5/11/2018	6:55:00 AM	0.2
BC05954	WAREHOUSE - TOOL ROOM - DRINKING FOUNTAIN RIGHT	5/11/2018	6:56:00 AM	0.18
BC05955	WAREHOUSE - TOOL ROOM - BOTTLE FILL	5/11/2018	6:56:00 AM	0.2
BC05956	WAREHOUSE - TOOL ROOM - SINK	5/11/2018	6:57:00 AM	0.32
BC05957	WAREHOUSE - CARPENTRY SHOP - SINK	5/11/2018	6:59:00 AM	0.7
BC06383	M&C - 1ST FLOOR - METER READER SINK	5/25/2018	6:57:00 AM	0.63
BC06384	M&C - 1ST FLOOR - METER READER BOTTLE FILL INSTA HOT	5/25/2018	6:57:00 AM	<0.05
BC06385	M&C - 1ST FLOOR - METER READER COFFEE MAKER HOT WATER TAP	5/25/2018	6:58:00 AM	0.42
BC06386	M&C - 1ST FLOOR - WEIGHT ROOM DRINKING FOUNTAIN	5/25/2018	6:54:00 AM	<0.05
BC06387	M&C - 1ST FLOOR - WEIGHT ROOM BOTTLE FILL	5/25/2018	6:54:00 AM	<0.05
BC06388	M&C - 1ST FLOOR - FAMILY ROOM SINK	5/25/2018	7:12:00 AM	0.078
BC06389	M&C - 1ST FLOOR - MENS LOCKER ROOM DRINKING FOUNTAIN LEFT	5/25/2018	6:51:00 AM	<0.05
BC06390	M&C - 1ST FLOOR - MENS LOCKER ROOM DRINKING FOUNTAIN RIGHT	5/25/2018	6:52:00 AM	<0.05
BC06391	M&C - 1ST FLOOR - MENS LOCKER ROOM BOTTLE FILL	5/25/2018	6:52:00 AM	<0.05
BC06392	M&C - 1ST FLOOR - LUNCH ROOM SINK LEFT	5/25/2018	6:45:00 AM	0.09
BC06393	M&C - 1ST FLOOR - LUNCH ROOM SINK RIGHT	5/25/2018	6:45:00 AM	1.82
BC06394	M&C - 1ST FLOOR - LUNCH ROOM BOTTLE FILL INSTA HOT	5/25/2018	6:46:00 AM	0.08
BC06395	M&C - 1ST FLOOR - LUNCH ROOM COFFEE MAKER HOT WATER TAP	5/25/2018	6:47:00 AM	0.58
BC06396	M&C - 2ND FLOOR - KITCHENETTE SINK	5/25/2018	7:02:00 AM	0.93
BC06397	M&C - 2ND FLOOR - KITCHENETTE COFFEE MAKER HOT WATER TAP	5/25/2018	7:03:00 AM	0.12
BC06398	M&C - 2ND FLOOR - KITCHENETTE BOTTLE FILL INSTA HOT	5/25/2018	7:03:00 AM	<0.05
BC06399	M&C - 2ND FLOOR - ROOM 210 DRINKING FOUNTAIN LEFT	5/25/2018	7:06:00 AM	<0.05
BC06400	M&C - 2ND FLOOR - ROOM 210 DRINKING FOUNTAIN RIGHT	5/25/2018	7:07:00 AM	<0.05
BC06401	M&C - 2ND FLOOR - ROOM 210 BOTTLE FILL	5/25/2018	7:07:00 AM	<0.05
BC06726	OPERATIONS - 1ST FLOOR - OE KITCHENETTE - SINK	6/1/2018	4:50:00 AM	6.22
BC06727	OPERATIONS - 1ST FLOOR - OE KITCHENETTE - COFFEE HOT WATER T	6/1/2018	4:50:00 AM	2.14
BC06728	OPERATIONS - 1ST FLOOR - LOBBY - DRINKING FOUNTAIN LEFT	6/1/2018	7:06:00 AM	<0.05
BC06729	OPERATIONS - 1ST FLOOR - LOBBY - DRINKING FOUNTAIN RIGHT	6/1/2018	7:06:00 AM	<0.05
BC06730	OPERATIONS - 1ST FLOOR - LOBBY - BOTTLE FILL	6/1/2018	7:07:00 AM	<0.05
BC06731	OPERATIONS - 1ST FLOOR - INSTRUMENT SHOP - SINK	6/1/2018	7:05:00 AM	2.92
BC06732	OPERATIONS - 2ND FLOOR - KITCHENETTE - SINK	6/1/2018	7:09:00 AM	1.94
BC06733	OPERATIONS - 2ND FLOOR - KITCHENETTE - INSTA HOT	6/1/2018	7:10:00 AM	0.24
BC06734	OPERATIONS - 2ND FLOOR - KITCHENETTE - DRINKING FOUNTAIN	6/1/2018	7:11:00 AM	<0.05
BC06735	OPERATIONS - 2ND FLOOR - KITCHENETTE - BOTTLE FILL	6/1/2018	7:11:00 AM	<0.05
BC06736	OPERATIONS - 2ND FLOOR - ROOM 220 - SINK	5/31/2018	7:40:00 AM	7.38
BC06737	OPERATIONS - 2ND FLOOR - ROOM 223 - SINK	6/1/2018	7:16:00 AM	13.2
BC06738	METER SHOP - SHOP DRINKING FOUNTAIN	6/1/2018	6:50:00 AM	0.4
BC06739	METER SHOP - BREAKROOM SINK	6/1/2018	6:51:00 AM	1.15
BC06809	OPERATIONS - 2ND FLOOR - WCC - SINK	6/1/2018	7:13:00 AM	1.64

ppb = parts per billion