



Nick Fish, Commissioner
Michael Stuhr, P.E., Administrator

1120 SW 5th Avenue, Room 600
Portland, Oregon 97204-1926
Information: 503-823-7404
www.portlandoregon.gov/water



July 2, 2018

Jeff Winkler
Sr. Management Analyst
City of Portland - Office of Management and Finance
1120 SW 5th Ave
Portland, OR 97204

RE: Sample Results for City Hall

Dear Jeff,

Attached you will find the lead results for the water samples collected at City Hall on June 19, 2018. Samples were collected in accordance with the protocol outlined in the EPA Technical Guidance, *3Ts for Reducing Lead in Drinking Water in Schools*. The samples were subsequently analyzed at the Portland Water Bureau Laboratory via EPA Method 200.8, an approved method for the analysis of lead in drinking water.

The EPA recommends follow-up testing if lead concentrations in any sample exceeds 20 parts per billion (ppb) to pinpoint the source(s) of lead contamination in your facility. Steps should be taken to mitigate elevated lead levels. Potential mitigation strategies, as well as sampling protocols, are outlined in the EPA guidance - *3Ts for Reducing Lead in Drinking Water in Schools*.

We encourage you to share these results with the public as soon as possible.

Please let us know if you have any questions on these results or any of the other information provided here.

Sincerely,

Yone Akagi, P.E.
Water Quality Manager
Portland Water Bureau



**Portland Water Bureau
Laboratory Report**

OR 100014

City Hall

PWB Sample ID	Location Description	Date Collected	Time Collected	Lead (ppb)
BC07506	FL1 - RM110 - BREAKROOM SINK	6/19/2018	5:54:00 AM	0.78
BC07507	FL1 - RM110 - BREAKROOM WATER COOLER	6/19/2018	5:55:00 AM	<0.05
BC07508	FL1 - MENS RESTROOM DRINKING FOUNTAIN	6/19/2018	5:50:00 AM	0.26
BC07509	FL1 - WOMENS RESTROOM DRINKING FOUNTAIN	6/19/2018	6:16:00 AM	0.16
BC07510	FL1- RM120 - BREAKROOM SINK	6/19/2018	6:01:00 AM	0.89
BC07511	FL1- RM120 - BREAKROOM WATER COOLER	6/19/2018	6:01:00 AM	0.38
BC07512	FL1 - RM130 - BREAKROOM SINK	6/19/2018	6:09:00 AM	0.31
BC07513	FL1 - RM130 - BREAKROOM WATER COOLER	6/19/2018	6:09:00 AM	0.23
BC07514	FL1 - HAPPY CUP COFFEE BAR - SINGLE SINK	6/19/2018	5:45:00 AM	0.51
BC07515	FL1 - HAPPY CUP COFFEE BAR - DOUBLE SINK LEFT	6/19/2018	5:42:00 AM	0.076
BC07516	FL1 - HAPPY CUP COFFEE BAR - DOUBLE SINK RIGHT	6/19/2018	5:43:00 AM	0.15
BC07517	FL1 - HAPPY CUP COFFEE BAR - COFFEE MAKER HOT TAP	6/19/2018	5:44:00 AM	1.4
BC07518	FL1 - HAPPY CUP COFFEE BAR - ICE MACHINE	6/19/2018	5:46:00 AM	<0.05
BC07519	FL2 - MENS RESTROOM DRINKING FOUNTAIN	6/19/2018	6:19:00 AM	0.26
BC07520	FL2 - WOMENS RESTROOM DRINKING FOUNTAIN	6/19/2018	6:45:00 AM	0.25
BC07521	FL2 - RM210 - BREAKROOM SINK	6/19/2018	6:27:00 AM	0.96
BC07522	FL2 - RM210 - BREAKROOM WATER COOLER	6/19/2018	6:27:00 AM	3.55
BC07523	FL2 - RM220 - BREAKROOM SINK	6/19/2018	6:34:00 AM	1.57
BC07524	FL2 - RM220 - BREAKROOM WATER COOLER	6/19/2018	6:35:00 AM	0.69
BC07525	FL2 - RM230 - BREAKROOM SINK	6/19/2018	6:41:00 AM	1.17
BC07526	FL2 - RM230 - BREAKROOM WATER COOLER	6/19/2018	6:42:00 AM	0.23
BC07527	FL2 - RM240 - BREAKROOM SINK	6/19/2018	6:52:00 AM	1.81
BC07528	FL2 - RM240 - BREAKROOM WATER COOLER	6/19/2018	6:53:00 AM	0.24
BC07529	FL3 - MENS RESTROOM DRINKING FOUNTAIN	6/19/2018	6:56:00 AM	0.33
BC07530	FL3 - WOMENS RESTROOM DRINKING FOUNTAIN	6/19/2018	7:14:00 AM	0.17
BC07531	FL3 - RM310 - BREAKROOM SINK	6/19/2018	7:00:00 AM	1.32
BC07532	FL3 - RM320 - BREAKROOM SINK	6/19/2018	7:06:00 AM	1
BC07533	FL3 - RM320 - BREAKROOM WATER COOLER	6/19/2018	7:06:00 AM	0.21
BC07534	FL3 - MOTHERS ROOM - SINK	6/19/2018	7:10:00 AM	2.11
BC07535	FL3 - RM340 - BREAKROOM SINK	6/19/2018	7:19:00 AM	0.85
BC07536	FL4 - MENS RESTROOM DRINKING FOUNTAIN	6/19/2018	7:25:00 AM	0.26
BC07537	FL4 - WOMENS RESTROOM DRINKING FOUNTAIN	6/19/2018	7:49:00 AM	0.19
BC07538	FL4 - RM410 - BREAKROOM SINK	6/19/2018	7:34:00 AM	2.46
BC07539	FL4 - RM410 - BREAKROOM WATER COOLER	6/19/2018	7:34:00 AM	0.7
BC07540	FL4 - RM420 - BREAKROOM SINK	6/19/2018	7:45:00 AM	0.44
BC07541	FL4 - RM430 - BREAKROOM SINK	6/19/2018	7:41:00 AM	0.6



**Portland Water Bureau
Laboratory Report**
OR 100014

City Hall

PWB Sample ID	Location Description	Date Collected	Time Collected	Lead (ppb)
BC07542	FL4 - RM430 - BREAKROOM WATER COOLER	6/19/2018	7:40:00 AM	0.2
BC07652	FL3 - RM340 - BREAKROOM WATER COOLER	6/19/2018	7:20:00 AM	0.19

ppb = parts per billion