



Nick Fish, Commissioner
Michael Stuhr, P.E., Administrator

1120 SW 5th Avenue, Room 600
Portland, Oregon 97204-1926
Information: 503-823-7404
www.portlandoregon.gov/water



July 30, 2018

Jeff Winkler
Sr. Management Analyst
City of Portland - Office of Management and Finance
1120 SW 5th Ave
Portland, OR 97204

RE: Sample Results for the Justice Center

Dear Jeff,

Attached you will find the lead results for the water samples collected at the Justice Center in June 2018. Samples were collected in accordance with the protocol outlined in the EPA Technical Guidance, *3Ts for Reducing Lead in Drinking Water in Schools*. The samples were subsequently analyzed at the Portland Water Bureau Laboratory via EPA Method 200.8, an approved method for the analysis of lead in drinking water.

The EPA recommends follow-up testing if lead concentrations in any sample exceeds 20 parts per billion (ppb) to pinpoint the source(s) of lead contamination in your facility. Steps should be taken to mitigate elevated lead levels. Potential mitigation strategies, as well as sampling protocols, are outlined in the EPA guidance - *3Ts for Reducing Lead in Drinking Water in Schools*.

We encourage you to share these results with the public as soon as possible.

Please let us know if you have any questions on these results or any of the other information provided here.

Sincerely,

Yone Akagi, P.E.
Water Quality Manager
Portland Water Bureau



**Portland Water Bureau
Laboratory Report
OR 100014**

Justice Center

PWB Sample ID	Location Description	Date Collected	Time Collected	Lead (ppb)
BC07774	FL1 - PRECINCT LOBBY DRINKING FOUNTAIN	6/26/2018	5:38:00 AM	4.8
BC07775	FL1 - PRECINCT BREAK ROOM SINK	6/26/2018	5:54:00 AM	0.54
BC07776	FL1 - PRECINCT BACK HALL DRINKING FOUNTAIN	6/26/2018	5:52:00 AM	<0.05
BC07777	FL1 - PRECINCT BACK HALL DRINKING FOUNTAIN BOTTLE FILL	6/26/2018	5:47:00 AM	<0.05
BC07778	FL11 - ELEVATOR LOBBY DRINKING FOUNTAIN	6/26/2018	7:43:00 AM	<0.05
BC07779	FL11 - ELEVATOR LOBBY DRINKING FOUNTAIN BOTTLE FILLER	6/26/2018	7:44:00 AM	<0.05
BC07780	FL11 - EAST SIDE RECORDS BREAK ROOM SINK	6/26/2018	7:48:00 AM	0.59
BC07781	FL11 - SECURE SIDE WEST HALL DRINKING FOUNTAIN	6/26/2018	7:56:00 AM	<0.05
BC07782	FL11 - SECURE SIDE WEST HALL DRINKING FOUNTAIN BOTTLE	6/26/2018	7:57:00 AM	<0.05
BC07783	FL11 - SECURE SIDE WEST BREAK ROOM SINK	6/27/2018	6:17:00 AM	5.49
BC07784	FL12 - ELEVATOR LOBBY DRINKING FOUNTAIN	6/26/2018	7:07:00 AM	<0.05
BC07785	FL12 - ELEVATOR LOBBY DRINKING FOUNTAIN BOTTLE FILLER	6/26/2018	7:09:00 AM	<0.05
BC07786	FL12 - FED EAST BREAK ROOM SINK	6/26/2018	7:14:00 AM	2.6
BC07787	FL12 - FED EAST BREAK ROOM SINK HOT TAP	6/26/2018	7:14:00 AM	0.47
BC07788	FL12 - WEST EVIDENCE PROCESSING ROOM SINK	6/26/2018	7:22:00 AM	2.12
BC07789	FL12 - SECURE SIDE WEST HALL DRINKING FOUNTAIN	6/26/2018	7:32:00 AM	3.45
BC07790	FL13 - ELEVATOR LOBBY DRINKING FOUNTAIN	6/26/2018	6:46:00 AM	<0.05
BC07791	FL13 - ELEVATOR LOBBY DRINKING FOUNTAIN BOTTLE FILLER	6/26/2018	6:47:00 AM	<0.05
BC07792	FL13 - SECURE SIDE WEST BREAK ROOM SINK	6/26/2018	7:00:00 AM	10.7
BC07793	FL13 - SECURE SIDE WEST BREAK ROOM SINK HOT TAP	6/26/2018	7:00:00 AM	0.38
BC07794	FL13 - SECURE SIDE WEST HALL DRINKING FOUNTAIN	6/26/2018	6:54:00 AM	<0.05
BC07795	FL13 - SECURE SIDE WEST HALL DRINKING FOUNTAIN BOTTLE	6/26/2018	6:56:00 AM	<0.05
BC07796	FL14 - ELEVATOR LOBBY DRINKING FOUNTAIN	6/26/2018	6:23:00 AM	<0.05
BC07797	FL14 - ELEVATOR LOBBY DRINKING FOUNTAIN BOTTLE FILLER	6/26/2018	6:24:00 AM	<0.05
BC07798	FL14 - EAST SIDE SULLIVAN ROOM SINK	6/26/2018	6:28:00 AM	2.02
BC07799	FL14 - PUBLIC BREAK ROOM SINK	6/26/2018	6:33:00 AM	1.97
BC07800	FL14 - PUBLIC BREAK ROOM SINK HOT TAP	6/26/2018	6:33:00 AM	0.58
BC07801	FL14 - SECURE SIDE WEST BREAK ROOM SINK	6/26/2018	6:41:00 AM	9.92
BC07802	FL14 - SECURE SIDE WEST HALL DRINKING FOUNTAIN	6/26/2018	6:37:00 AM	<0.05
BC07803	FL14 - SECURE SIDE WEST HALL DRINKING FOUNTAIN BOTTLE	6/26/2018	6:39:00 AM	<0.05
BC07804	FL15 - ELEVATOR LOBBY DRINKING FOUNTAIN	6/26/2018	6:07:00 AM	<0.05
BC07805	FL15 - ELEVATOR LOBBY DRINKING FOUNTAIN BOTTLE FILLER	6/26/2018	6:08:00 AM	<0.05
BC07806	FL15 - CHIEFS OFFICE EAST SIDE BREAK ROOM SINK	6/26/2018	6:11:00 AM	2.24
BC07807	FL15 - SECURE SIDE WEST HALL DRINKING FOUNTAIN	6/26/2018	6:14:00 AM	<0.05
BC07808	FL15 - SECURE SIDE WEST HALL DRINKING FOUNTAIN BOTTLE	6/26/2018	6:15:00 AM	<0.05
BC07809	FL15 - SECURE SIDE WEST BREAK ROOM SINK	6/26/2018	6:17:00 AM	13
BC07810	FL16 - GYM DRINKING FOUNTAIN	6/26/2018	6:00:00 AM	<0.05



Portland Water Bureau
Laboratory Report
OR 100014

Justice Center

PWB Sample ID	Location Description	Date Collected	Time Collected	Lead (ppb)
BC07811	FL16 - GYM DRINKING FOUNTAIN BOTTLE FILLER	6/26/2018	6:01:00 AM	<0.05
BC08145	FL12 - SECURE WEST SIDE SUPPLY ROOM KITCHEN SINK	6/27/2018	6:23:00 AM	16.3
BC08146	FL12 - RM1221 KITCHEN SINK	6/27/2018	6:28:00 AM	0.58

ppb = parts per billion