



Amanda Fritz, Commissioner
Michael Stuhr, P.E., Administrator

1120 SW 5th Avenue, Room 600
Portland, Oregon 97204-1926
Information: 503-823-7404
www.portlandoregon.gov/water



September 4, 2018

Jeff Winkler
Sr. Management Analyst
City of Portland - Office of Management and Finance
1120 SW 5th Ave
Portland, OR 97204

RE: Sample Results for Graham Garage

Dear Jeff,

Attached you will find the lead results for the water samples collected at Graham Garage on July 3, 2018. Samples were collected in accordance with the protocol outlined in the EPA Technical Guidance, *3Ts for Reducing Lead in Drinking Water in Schools*. The samples were subsequently analyzed at the Portland Water Bureau Laboratory via EPA Method 200.8, an approved method for the analysis of lead in drinking water.

The EPA recommends follow-up testing if lead concentrations in any sample exceeds 20 parts per billion (ppb) to pinpoint the source(s) of lead contamination in your facility. Steps should be taken to mitigate elevated lead levels. Potential mitigation strategies, as well as sampling protocols, are outlined in the EPA guidance - *3Ts for Reducing Lead in Drinking Water in Schools*.

We encourage you to share these results with the public as soon as possible.

Please let us know if you have any questions on these results or any of the other information provided here.

Sincerely,

Yone Akagi, P.E.
Water Quality Manager
Portland Water Bureau



**Portland Water Bureau
Laboratory Report**

Graham Garage (City Fleet Body Shop)

PWB Sample ID	Location Description	Date Collected	Time Collected	Lead (ppb)
BC08358	FL1 - LOCKER ROOM DRINKING FOUNTAIN	7/3/2018	6:36:00 AM	0.7
BC08359	FL1 - LOCKER ROOM UTILITY SINK	7/3/2018	6:37:00 AM	0.62
BC08360	FL2 - BREAK ROOM SINK	7/3/2018	6:39:00 AM	2.32
BC08361	FL2 - BREAK ROOM WATER COOLER	7/3/2018	6:40:00 AM	0.63

ppb = parts per billion