



Amanda Fritz, Commissioner
Michael Stuhr, P.E., Administrator

1120 SW 5th Avenue, Room 600
Portland, Oregon 97204-1926
Information: 503-823-7404
www.portlandoregon.gov/water



September 4, 2018

Jeff Winkler
Sr. Management Analyst
City of Portland - Office of Management and Finance
1120 SW 5th Ave
Portland, OR 97204

RE: Sample Results for the East Precinct

Dear Jeff,

Attached you will find the lead results for the water samples collected at the East Precinct on June 22 and June 25, 2018. Samples were collected in accordance with the protocol outlined in the EPA Technical Guidance, *3Ts for Reducing Lead in Drinking Water in Schools*. The samples were subsequently analyzed at the Portland Water Bureau Laboratory via EPA Method 200.8, an approved method for the analysis of lead in drinking water.

The EPA recommends follow-up testing if lead concentrations in any sample exceeds 20 parts per billion (ppb) to pinpoint the source(s) of lead contamination in your facility. Steps should be taken to mitigate elevated lead levels. Potential mitigation strategies, as well as sampling protocols, are outlined in the EPA guidance - *3Ts for Reducing Lead in Drinking Water in Schools*.

We encourage you to share these results with the public as soon as possible.

Please let us know if you have any questions on these results or any of the other information provided here.

Sincerely,

Yone Akagi, P.E.
Water Quality Manager
Portland Water Bureau



**Portland Water Bureau
Laboratory Report**

FROM FOREST TO FAUCET OR 100014

East Precinct

PWB Sample ID	Location Description	Date Collected	Time Collected	Lead (ppb)
BC07731	FL1 - COMMUNITY ROOM SINK	6/22/2018	8:27:00 AM	1.97
BC07732	FL1 - COMMUNITY ROOM SINK HOT TAP	6/22/2018	8:28:00 AM	0.83
BC07733	FL1 - GREEN SPACE KITCHENETTE SINK	6/22/2018	8:32:00 AM	0.23
BC07734	FL1 - GREEN SPACE KITCHENETTE SINK FILTERED TAP	6/22/2018	8:33:00 AM	1.15
BC07735	FL1 - GREEN SPACE KITCHENETTE ICE MACHINE	6/25/2018	9:30:00 AM	<0.05
BC07736	FL1 - STAIRWAY DRINKING FOUNTAIN LEFT	6/22/2018	8:53:00 AM	0.2
BC07737	FL1 - STAIRWAY DRINKING FOUNTAIN RIGHT	6/22/2018	8:55:00 AM	0.067
BC07738	FL1 - LOBBY DRINKING FOUNTAIN LEFT	6/22/2018	8:24:00 AM	0.092
BC07739	FL1 - LOBBY DRINKING FOUNTAIN RIGHT	6/22/2018	8:25:00 AM	0.15
BC07740	FL1 - LOBBY DRINKING FOUNTAIN RIGHT BOTTLE FILLER	6/22/2018	8:24:00 AM	0.13
BC07741	FL2 - BREAKROOM SINK	6/22/2018	8:40:00 AM	1.64
BC07743	FL2 - GYM DRINKING FOUNTAIN	6/22/2018	8:45:00 AM	<0.05
BC07744	FL2 - GYM DRINKING FOUNTAIN BOTTLE FILLER	6/22/2018	8:45:00 AM	<0.05

ppb = parts per billion