

**Table 1. Sample Locations and Analytical Results
Rose Quater
Veterans Memorial Coliseum**

Building	Sample ID (Laboratory Sample ID)	Sample Date	Type of Source	Location in Building	Lead Concentration (µg/L)
Veterans Memorial Coliseum	Coke A - FD (A7C0629-01)	3/20/2017	Selmix Revere Serial No. AR-14410	Second Floor Concession Stand A. First Coca-Cola machine.	0.767
Veterans Memorial Coliseum	Coke A - FF (A7C0629-02)	3/20/2017	Selmix Revere Serial No. AR-14410	Second Floor Concession Stand A. First Coca-Cola machine.	0.756
Veterans Memorial Coliseum	Coke C - FD (A7C0629-03)	3/20/2017	Selmix Revere Serial No. AR-14206	Second Floor Concession Stand C. First Coca-Cola machine.	2.87
Veterans Memorial Coliseum	Coke C - FF (A7C0629-04)	3/20/2017	Selmix Revere Serial No. AR-14206	Second Floor Concession Stand C. First Coca-Cola machine.	2.91
Veterans Memorial Coliseum	Coke E - FD (A7C0629-05)	3/20/2017	Automatic Bar Control. Model No. WBM-85160-R-FR Serial No. R8396-106	Second Floor Concession Stand E. Second soda dispenser gun.	7.60
Veterans Memorial Coliseum	Coke E - FF (A7C0629-06)	3/20/2017	Automatic Bar Control. Model No. WBM-85160-R-FR Serial No. R8396-106	Second Floor Concession Stand E. Second soda dispenser gun.	4.66
Veterans Memorial Coliseum	Coke F - FD (A7C0629-07)	3/20/2017	Selmix Revere Serial No. AR-14174	Second Floor Concession Stand F. First Coca-Cola machine.	4.36
Veterans Memorial Coliseum	Coke F - FF (A7C0629-08)	3/20/2017	Selmix Revere Serial No. AR-14174	Second Floor Concession Stand F. First Coca-Cola machine.	2.90
Veterans Memorial Coliseum	Coke K - FD (A7C0629-09)	3/20/2017	Selmix Revere Serial No. AR-14184	Second Floor Concession Stand K. First Coca-Cola machine.	1.09
Veterans Memorial Coliseum	Coke K - FF (A7C0629-10RE1)	3/20/2017	Selmix Revere Serial No. AR-14184	Second Floor Concession Stand K. First Coca-Cola machine.	0.711
Veterans Memorial Coliseum	Coke M - FD (A7C0629-11)	3/20/2017	Selmix Revere Serial No. AR-14482	Second Floor Concession Stand M. First Coca-Cola machine.	9.72
Veterans Memorial Coliseum	Coke M - FF (A7C0629-12)	3/20/2017	Selmix Revere Serial No. AR-14482	Second Floor Concession Stand M. First Coca-Cola machine.	7.38
Veterans Memorial Coliseum	Coke S - FD (A7C0629-13)	3/20/2017	Selmix Revere Serial No. AR-13687	Second Floor Concession Stand S. First Coca-Cola machine.	5.94
Veterans Memorial Coliseum	Coke S - FF (A7C0629-14)	3/20/2017	Selmix Revere Serial No. AR-13687	Second Floor Concession Stand S. First Coca-Cola machine.	4.01
Veterans Memorial Coliseum	Coke U - FD (A7C0629-15)	3/20/2017	Selmix Revere	First Floor Concession Stand U. First Coca-Cola machine.	8.59
Veterans Memorial Coliseum	Coke U - FF (A7C0629-16)	3/20/2017	Selmix Revere	First Floor Concession Stand U. First Coca-Cola machine.	6.04
Veterans Memorial Coliseum	Coffee - FD (A7C0629-17)	3/20/2017	Fetco Coffee Brewer Model No. CBS-2052e Serial No. 480233078277	First Floor Kitchen. Coffee machine along the wall, left dispenser.	0.767
Veterans Memorial Coliseum	Coffee - FF (A7C0629-18)	3/20/2017	Fetco Coffee Brewer Model No. CBS-2052e Serial No. 480233078277	First Floor Kitchen. Coffee machine along the wall, left dispenser.	0.656
Veterans Memorial Coliseum	Gatorade - FD (A7C0629-19RE1)	3/20/2017	Polyethylene water filter dispenser	First Floor Home Locker Room. Water dispenser next to washing machine.	0.200 U
Veterans Memorial Coliseum	Gatorade - FF (A7C0629-20RE1)	3/20/2017	Polyethylene water filter dispenser	First Floor Home Locker Room. Water dispenser next to washing machine.	0.200 U
Veterans Memorial Coliseum	Commissary Ice (A7C0629-21)	3/20/2017	Ice-O-Matic Model No. ICE1006HAS Serial No. 13091280012000	First Floor Commissary. Large, main ice machine for Veterans Memorial Coliseum.	0.200 U
Veterans Memorial Coliseum	Kitchen Ice (A7C0629-22RE1)	3/20/2017	Ice-O-Matic Model No. B55PPA Serial No. P800-10926-2	First Floor Kitchen. Ice machine in middle of kitchen.	0.200 U
Veterans Memorial Coliseum	Concession K Ice (A7C0629-23)	3/20/2017	Crystal Tips Ice Systems Model No. BRS-1000 Serial No. 123505-07M	Second Floor Concession Stand K. Ice machine in back room.	0.200 U
Veterans Memorial Coliseum	DF BB-FD	4/14/2017	Unknown	Second Floor Drinking Fountain. Next to Arena Entrance BB.	6.62
Veterans Memorial Coliseum	DF BB-FF	4/14/2017	Unknown	Second Floor Drinking Fountain. Next to Arena Entrance BB.	0.322
Veterans Memorial Coliseum	DF HH-FD	4/14/2017	Sunroc Model No. SF-3400 Lot #51302 Rev#3A	Second Floor Drinking Fountain. Next to Arena Entrance HH.	1.4
Veterans Memorial Coliseum	DF HH-FF	4/14/2017	Sunroc Model No. SF-3400 Lot #51302 Rev#3A	Second Floor Drinking Fountain. Next to Arena Entrance HH.	0.200 U

**Table 1. Sample Locations and Analytical Results
Rose Quarter
Veterans Memorial Coliseum**

Building	Sample ID (Laboratory Sample ID)	Sample Date	Type of Source	Location in Building	Lead Concentration (µg/L)
Veterans Memorial Coliseum	DF LL-FD	4/14/2017	Sunroc Model No. SF-3400 Lot #51302 Rev#3A	Second Floor Drinking Fountain. Next to Arena Entrance LL.	1.63
Veterans Memorial Coliseum	DF LL-FF	4/14/2017	Sunroc Model No. SF-3400 Lot #51302 Rev#3A	Second Floor Drinking Fountain. Next to Arena Entrance LL.	0.200 U
Veterans Memorial Coliseum	DF SS-FD	4/14/2017	Elkay Model No. EHWM214C_A Serial No. 160730944	Second Floor Drinking Fountain. Next to Arena Entrance SS.	2.51
Veterans Memorial Coliseum	DF SS-FF	4/14/2017	Elkay Model No. EHWM214C_A Serial No. 160730944	Second Floor Drinking Fountain. Next to Arena Entrance SS.	2.31
Veterans Memorial Coliseum	WH Off-FD	4/14/2017	Elkay Model No. EHWM214C_A Serial No. 160730947	First Floor Drinking Fountain. Near old Winterhawks office, right side of the main Exhibit Hall entrance hallway.	3.4
Veterans Memorial Coliseum	WH Off-FF	4/14/2017	Elkay Model No. EHWM214C_A Serial No. 160730947	First Floor Drinking Fountain. Near old Winterhawks office, right side of the main Exhibit Hall entrance hallway.	3.67
Veterans Memorial Coliseum	WH Tix-FD	4/14/2017	Elkay Model No. EHWM214C_A Serial No. 160730945	First Floor Drinking Fountain. Near old Winterhawks ticket office, left side of the main Exhibit Hall entrance hallway.	1.61
Veterans Memorial Coliseum	WH Tix-FF	4/14/2017	Elkay Model No. EHWM214C_A Serial No. 160730945	First Floor Drinking Fountain. Near old Winterhawks ticket office, left side of the main Exhibit Hall entrance hallway.	0.818
Veterans Memorial Coliseum	DF Exhibit-FD	4/14/2017	Elkay Model No. EMABFD_B Serial No. 151020688	First Floor Drinking Fountain. Located in Exhibit hall near restrooms.	4.06
Veterans Memorial Coliseum	DF Exhibit-FF	4/14/2017	Elkay Model No. EMABFD_B Serial No. 151020688	First Floor Drinking Fountain. Located in Exhibit hall near restrooms.	1.34
Veterans Memorial Coliseum	DF Weyer R - FD	4/14/2017	Haws Model No. HC8SR Serial No. 016577956 E89	First Floor Drinking Fountain. Located outside of Weyerhaeuser room, right fountain.	6.34
Veterans Memorial Coliseum	DF Weyer R - FF	4/14/2017	Haws Model No. HC8SR Serial No. 016577956 E89	First Floor Drinking Fountain. Located outside of Weyerhaeuser room, right fountain.	6.33
Veterans Memorial Coliseum	DF Weyer L - FD	4/14/2017	Haws Model No. HC8SR Serial No. 016577959 E89	First Floor Drinking Fountain. Located outside of Weyerhaeuser room, left fountain.	10.3
Veterans Memorial Coliseum	DF Weyer L - FF	4/14/2017	Haws Model No. HC8SR Serial No. 016577959 E89	First Floor Drinking Fountain. Located outside of Weyerhaeuser room, left fountain.	7.6
Veterans Memorial Coliseum	DF PT L - FD	4/14/2017	Elkay Model No. EHWM214C_A Serial No. 160730946	First Floor Drinking Fountain. Near Pope and Talbot room, left fountain.	10.7
Veterans Memorial Coliseum	DF PT L - FF	4/14/2017	Elkay Model No. EHWM214C_A Serial No. 160730946	First Floor Drinking Fountain. Near Pope and Talbot room, left fountain.	8.19
Veterans Memorial Coliseum	DF PT R - FD	4/14/2017	Elkay Model No. EHWM214C_A Serial No. 160730942	First Floor Drinking Fountain. Near Pope and Talbot room, right fountain.	9.97
Veterans Memorial Coliseum	DF PT R - FF	4/14/2017	Elkay Model No. EHWM214C_A Serial No. 160730942	First Floor Drinking Fountain. Near Pope and Talbot room, right fountain.	0.849
Veterans Memorial Coliseum	DF Arena Men - FD	4/14/2017	Elkay Model No. ESWA8_1K Serial No. 121019979	First Floor Drinking Fountain. Located outside of Winterhawks locker room south of the arena, near mens restroom.	1.32
Veterans Memorial Coliseum	DF Arena Men - FF	4/14/2017	Elkay Model No. ESWA8_1K Serial No. 121019979	First Floor Drinking Fountain. Located outside of Winterhawks locker room south of the arena, near mens restroom.	1.61
Veterans Memorial Coliseum	DF Arena Women - FD	4/14/2017	Elkay Model No. ESWA8_1K Serial No. 121019978	First Floor Drinking Fountain. Located south of the arena, near womens restroom.	0.294
Veterans Memorial Coliseum	DF Arena Women - FF	4/14/2017	Elkay Model No. ESWA8_1K Serial No. 121019978	First Floor Drinking Fountain. Located south of the arena, near womens restroom.	0.34
Veterans Memorial Coliseum	DF GP - FD	4/14/2017	Haws Model No. HC8SR Serial No. 016564708 D89	First Floor Drinking Fountain. Near southwest entrance of Georgia Pacific Room, at north entry of arena.	6.64
Veterans Memorial Coliseum	DF GP - FF	4/14/2017	Haws Model No. HC8SR Serial No. 016564708 D89	First Floor Drinking Fountain. Near southwest entrance of Georgia Pacific Room, at north entry of arena.	8.45

Notes, Abbreviations & Acronyms

ID = Identification

µg/L = micrograms per liter

U = The analyte was analyzed for, but was not detected above the level of the reported sample quantitation limit.

U.S. Environmental Protection Agency Action level for Public Water Supply = 15 µg/L

U.S. Environmental Protection Agency Action level for drinking water source = 20 µg/L