



Nick Fish, Commissioner
Michael Stuhr, P.E., Administrator

1120 SW 5th Avenue, Room 600
Portland, Oregon 97204-1926
Information: 503-823-7404
www.portlandoregon.gov/water



November 13, 2018

Kyle DeHart
Health Safety & Environmental Specialist
Portland Parks & Recreation
1050 SW 6th Ave, Suite 2200
Portland, OR 97204

RE: Post-remediation Sample Result for the Portland Children's Museum

Dear Kyle,

Attached you will find the post-remediation lead result for the water sample collected at the Portland Children's Museum on October 2, 2018. The sample was collected in accordance with the protocol outlined in the EPA Technical Guidance, *3Ts for Reducing Lead in Drinking Water in Schools*. The sample was subsequently analyzed at the Portland Water Bureau Laboratory via EPA Method 200.8, an approved method for the analysis of lead in drinking water.

The EPA recommends follow-up testing if lead concentrations in any sample exceeds 20 parts per billion (ppb) to pinpoint the source(s) of lead contamination in your facility. Steps should be taken to mitigate elevated lead levels. Potential mitigation strategies, as well as sampling protocols, are outlined in the EPA guidance - *3Ts for Reducing Lead in Drinking Water in Schools*.

We encourage you to share this result with the public as soon as possible.

Please let us know if you have any questions on these results or any of the other information provided here.

Sincerely,

Yone Akagi, P.E.
Water Quality Manager
Portland Water Bureau



**Portland Water Bureau
Laboratory Report**

FROM FOREST TO FAUCET OR 100014

Portland Children's Museum (Post-remediation)

PWB Sample ID	Location Description	Date Collected	Time Collected	Lead (ppb)
BC13201	3rd Floor Left Fountain	10/2/2018	7:05:00 AM	3.98

ppb = parts per billion



Amanda Fritz, Commissioner
Michael Stuhr, P.E., Administrator

1120 SW 5th Avenue, Room 600
Portland, Oregon 97204-1926
Information: 503-823-7404
www.portlandoregon.gov/water



April 10, 2019

Chris Silkie, PE, LEED AP, CEM
Asset Management Program Manager
Portland Parks & Recreation
6437 SE Division St, Suite 416
Portland, OR 97206

RE: Sample Results

Dear Chris,

Attached you will find the lead results for the water samples collected at your facility. The samples were collected in accordance with the protocol outlined in the EPA Technical Guidance, *3Ts for Reducing Lead in Drinking Water in Schools (2018)*. The samples were subsequently analyzed at the Portland Water Bureau Laboratory via EPA Method 200.8, an approved method for the analysis of lead in drinking water.

Sampling protocols and potential mitigation strategies are outlined in the EPA guidance - *3Ts for Reducing Lead in Drinking Water in Schools (2018)*.

We encourage you to share these results with the public as soon as possible.

Please let us know if you have any questions on these results or any of the other information provided here.

Sincerely,

Yone Akagi, P.E.
Water Quality Manager
Portland Water Bureau

Laboratory Report

ORELAP Accreditation Number: OR 100014



Chris Silke, PE, LEED AP, CEM
Portland Children's Museum
6437 SE Division St Suite 416
Portland OR 97206

Lab ID	Collection Date / Time	Sample Location	Sample Type	Lead (ppb)
BC20758	3/12/2019 7:10:00 AM	Room #143 Sink	First-draw Repeat	17.4

ppb = parts per billion

Sample Types:

First-draw = Sample collected after an 8 to 18 hour stagnation period

Flowing = Sample collected after running water for 30 seconds