



Nick Fish, Commissioner  
Michael Stuhr, P.E., Administrator

1120 SW 5<sup>th</sup> Avenue, Room 600  
Portland, Oregon 97204-1926  
Information: 503-823-7404  
[www.portlandoregon.gov/water](http://www.portlandoregon.gov/water)



November 13, 2018

Kyle DeHart  
Health Safety & Environmental Specialist  
Portland Parks & Recreation  
1050 SW 6<sup>th</sup> Ave, Suite 2200  
Portland, OR 97204

RE: Post-remediation Sample Result for the Portland Children's Museum

Dear Kyle,

Attached you will find the post-remediation lead result for the water sample collected at the Portland Children's Museum on October 2, 2018. The sample was collected in accordance with the protocol outlined in the EPA Technical Guidance, *3Ts for Reducing Lead in Drinking Water in Schools*. The sample was subsequently analyzed at the Portland Water Bureau Laboratory via EPA Method 200.8, an approved method for the analysis of lead in drinking water.

The EPA recommends follow-up testing if lead concentrations in any sample exceeds 20 parts per billion (ppb) to pinpoint the source(s) of lead contamination in your facility. Steps should be taken to mitigate elevated lead levels. Potential mitigation strategies, as well as sampling protocols, are outlined in the EPA guidance - *3Ts for Reducing Lead in Drinking Water in Schools*.

We encourage you to share this result with the public as soon as possible.

Please let us know if you have any questions on these results or any of the other information provided here.

Sincerely,

Yone Akagi, P.E.  
Water Quality Manager  
Portland Water Bureau



**Portland Water Bureau  
Laboratory Report**

FROM FOREST TO FAUCET OR 100014

**Portland Children's Museum (Post-remediation)**

<b>PWB Sample ID</b>	<b>Location Description</b>	<b>Date Collected</b>	<b>Time Collected</b>	<b>Lead (ppb)</b>
BC13201	3rd Floor Left Fountain	10/2/2018	7:05:00 AM	3.98

ppb = parts per billion